

ГноА.: 0.036 - 60.0_м3/ч Ду= мм
 Гобр.: 0.036 - 60.0_м3/ч Ду= мм
 Гп : 10 л/Имп

Посуточная ведомость учета параметров теплопотребления
 с 16.02.2023 по 16.03.2023

Дата	Q Гкал	Масса, тонн. Объем, м3			Температура, °С				Давление		Время, час		Классиф ошибок		
		M1	V1	M2	V2	M1-M2 разбор	t1	t2	t1-t2	txb	P1 атм	P2 атм		Нераб. Тн	Работы Тр
16.02.23	4.588	345.08	351.1240	345.24	349.0664	-0.16	61.6	48.3	13.3	0.0	6.5	5.5	0.00	24.00	
17.02.23	5.733	345.25	352.9082	345.43	350.0449	-0.18	69.9	53.3	16.6	0.0	6.5	5.5	0.00	24.00	
18.02.23	5.583	345.12	352.6367	345.40	349.9785	-0.28	69.2	53.0	16.2	0.0	6.5	5.4	0.00	24.00	
19.02.23	5.279	345.01	352.1016	345.35	349.7383	-0.34	67.1	51.8	15.3	0.0	6.5	5.4	0.00	24.00	
20.02.23	4.683	345.25	351.4629	345.65	349.5918	-0.41	62.5	48.9	13.6	0.0	6.5	5.5	0.00	24.00	
21.02.23	5.847	344.28	352.1914	344.64	349.4121	-0.36	71.3	54.3	17.0	0.0	6.5	5.4	0.00	24.00	
22.02.23	5.693	344.79	352.3730	345.12	349.7070	-0.33	69.6	53.1	16.5	0.0	6.5	5.4	0.00	24.00	
23.02.23	5.755	344.94	352.5293	345.32	349.8711	-0.38	69.6	52.9	16.7	0.0	6.5	5.5	0.00	24.00	
24.02.23	5.272	344.16	351.2051	344.50	348.8301	-0.34	66.8	51.5	15.3	0.0	6.5	5.4	0.00	24.00	
25.02.23	3.861	344.49	349.6855	344.91	348.3496	-0.43	56.8	45.6	11.2	0.0	6.5	5.4	0.00	24.00	
26.02.23	3.706	345.56	350.4023	346.03	349.2461	-0.47	54.7	44.0	10.7	0.0	6.6	5.5	0.00	24.00	
27.02.23	4.832	344.70	350.9648	345.08	348.9980	-0.38	62.9	48.9	14.0	0.0	6.5	5.5	0.00	24.00	
28.02.23	4.758	344.69	350.9414	345.08	349.0059	-0.39	62.7	48.9	13.8	0.0	6.5	5.5	0.00	24.00	
01.03.23	4.709	344.96	351.1426	345.38	349.2715	-0.42	62.3	48.7	13.6	0.0	6.5	5.5	0.00	24.00	
02.03.23	4.338	344.98	350.7129	345.41	349.0898	-0.42	59.8	47.3	12.6	0.0	6.5	5.5	0.00	24.00	
03.03.23	3.899	345.13	350.2539	345.58	348.9492	-0.45	56.4	45.1	11.3	0.0	6.5	5.5	0.00	24.00	
04.03.23	4.210	344.96	350.5625	345.43	349.0664	-0.47	59.2	47.0	12.2	0.0	6.5	5.5	0.00	24.00	
05.03.23	4.070	344.68	350.0527	345.14	348.6465	-0.46	57.9	46.1	11.8	0.0	6.6	5.5	0.00	24.00	
06.03.23	4.192	348.72	354.2793	349.20	352.8184	-0.47	58.6	46.6	12.0	0.0	6.6	5.5	0.00	24.00	
07.03.23	4.652	351.00	357.2461	351.50	355.4941	-0.50	62.1	48.9	13.2	0.0	6.6	5.5	0.00	24.00	
08.03.23	5.009	350.47	352.7207	350.95	355.2754	-0.49	65.3	51.0	14.3	0.0	6.6	5.5	0.00	24.00	
09.03.23	3.980	347.38	352.7207	347.88	351.4004	-0.50	57.4	46.0	11.4	0.0	6.5	5.4	0.00	24.00	
10.03.23	4.743	344.83	351.1387	345.27	349.2539	-0.44	63.1	49.3	13.7	0.0	6.5	5.5	0.00	24.00	
11.03.23	4.623	344.47	350.6758	344.88	348.8184	-0.41	62.5	49.1	13.4	0.0	6.5	5.5	0.00	24.00	
12.03.23	3.325	345.10	349.5566	345.64	348.6797	-0.54	52.3	42.6	9.6	0.0	6.6	5.5	0.00	24.00	
13.03.23	4.490	344.82	350.7852	345.27	349.0781	-0.45	61.2	48.2	13.0	0.0	6.6	5.5	0.00	24.00	
14.03.23	3.507	344.73	349.5020	345.20	348.4258	-0.48	54.2	44.1	10.2	0.0	6.6	5.4	0.00	24.00	
15.03.23	3.179	345.31	349.6055	345.80	348.7480	-0.49	51.3	42.1	9.2	0.0	6.6	5.5	0.00	24.00	
16.03.23	3.190	345.64	349.9805	346.15	349.1387	-0.51	51.6	42.4	9.2	0.0	6.5	5.4	0.00	24.00	
Итого	131.708	10020.4	10196.0713	10032.4	10143.9941	-11.95	61.4	48.2	13.1	0.0	6.6	5.5	0.00	696.00	0.00

03.23 24:00	544.189	25971.98	25990.93	26425.23	26277.45	1800.00
16.02.23 00:00	212.482	15951.50	15958.50	16229.16	16133.46	1104.00
Итого	131.708	10020.48	10032.43	10196.07	10143.99	696.00

Этчетный период _____ 696.00_час. Период норм. работы _____ 696.00_час.

Период отключения питания (U) _____ 0.000_час. Период функц.отказа (E) _____ 0.000_час.
 период t2-t1 < min (D) _____ 0.000_час. Период G<min (g) _____ 0.000_час.
 период G>max (G) _____ 0.000_час.

Представитель абонента _____ Представитель теллоснабжающей организации _____

