

Глод.: 0.036 - 60.0 м3/ч Ду= мм  
 Гобр.: 0.036 - 60.0 м3/ч Ду= мм  
 Гп : 10 л/Имп

Посуточная ведомость учета параметров теплопотребления  
 с 16.02.2023 по 16.03.2023

Дата	Q Гкал	Масса, тонн		Температура, °С			Время, час		Работы Тр	Классиф ошибок		
		М1	М2	М1-М2 утечка	VI	М2-М1 подмес	t1	t2			t1-t2	Нераб. Тн
16.02.23	3.197	250.2920	250.9619	-	0.00	0.6699	62.09	49.32	12.77	0.00	24.00	
17.02.23	3.951	250.2871	250.7891	-	0.00	0.5070	70.33	54.54	15.78	0.00	24.00	
18.02.23	3.788	250.2744	250.8193	-	0.00	0.5449	68.88	53.74	15.13	0.00	24.00	
19.02.23	3.596	250.1240	250.6670	-	0.00	0.5430	66.96	52.59	14.37	0.00	24.00	
20.02.23	3.279	250.1582	250.7549	-	0.00	0.5967	63.22	50.11	13.10	0.00	24.00	
21.02.23	4.016	249.5449	249.9990	-	0.00	0.4541	71.41	55.33	16.09	0.00	24.00	
22.02.23	3.944	250.0195	250.5322	-	0.00	0.5127	69.70	53.93	15.77	0.00	24.00	
23.02.23	3.975	250.0938	250.6211	-	0.00	0.5273	69.87	53.98	15.89	0.00	24.00	
24.02.23	3.519	249.8008	250.3564	-	0.00	0.5557	66.00	51.92	14.08	0.00	24.00	
25.02.23	2.631	250.5557	251.1797	-	0.00	0.6240	56.33	45.83	10.50	0.00	24.00	
26.02.23	2.598	250.6523	251.3447	-	0.00	0.6924	55.33	44.97	10.36	0.00	24.00	
27.02.23	3.288	249.9922	250.5332	-	0.00	0.5664	63.19	50.04	13.15	0.00	24.00	
28.02.23	3.174	249.9922	250.5654	-	0.00	0.5732	62.34	49.64	12.70	0.00	24.00	
01.03.23	3.225	250.0869	250.6680	-	0.00	0.5811	62.74	49.84	12.89	0.00	24.00	
02.03.23	2.926	250.1045	250.7139	-	0.00	0.6094	59.56	47.87	11.70	0.00	24.00	
03.03.23	2.649	250.3125	250.8887	-	0.00	0.5762	56.53	45.95	10.58	0.00	24.00	
04.03.23	2.857	250.1611	250.7363	-	0.00	0.5752	59.20	47.78	11.42	0.00	24.00	
05.03.23	2.779	249.8672	250.4248	-	0.00	0.5376	58.06	46.94	11.12	0.00	24.00	
06.03.23	2.876	253.2617	253.9268	-	0.00	0.6650	58.89	47.54	11.35	0.00	24.00	
07.03.23	3.187	254.4531	255.1367	-	0.00	0.6836	62.40	49.87	12.52	0.00	24.00	
08.03.23	3.309	253.5898	253.8965	-	0.00	0.3066	64.65	51.60	13.04	0.00	24.00	
09.03.23	2.731	249.9629	250.4492	-	0.00	0.4853	57.91	46.99	10.92	0.00	24.00	
10.03.23	3.233	248.4355	248.8438	-	0.00	0.4082	63.51	50.50	13.01	0.00	24.00	
11.03.23	3.029	248.0234	248.4727	-	0.00	0.4492	61.63	49.42	12.21	0.00	24.00	
12.03.23	2.340	248.6523	249.1172	-	0.00	0.4648	52.89	43.48	9.41	0.00	24.00	
13.03.23	3.016	248.4668	248.8984	-	0.00	0.4316	61.14	49.01	12.14	0.00	24.00	
14.03.23	2.289	248.3594	248.7832	-	0.00	0.4238	53.33	44.11	9.21	0.00	24.00	
15.03.23	2.153	248.6680	249.1094	-	0.00	0.4414	51.36	42.71	8.65	0.00	24.00	
16.03.23	2.187	251.9902	252.4082	-	0.00	0.4180	51.52	42.85	8.67	0.00	24.00	
Итого	89.739	7256.1572	7271.5977	0.0000	0.00	15.4403	61.41	49.05	12.36	0.00	696.00	0.00

Дата	Время	Q	М1	М2	VI	Тр

16.03.23 24:00	231.935	18695.47	18524.46	0.00	1797.09
16.02.23 00:00	142.195	11439.32	11252.86	0.00	1101.09
Итого	89.739	7256.16	7271.60	0.00	696.00

Этчетный период \_\_\_\_\_ 696.00\_час. Период норм. работы \_\_\_\_\_ 696.00\_час.

Период отключения питания (U) \_\_\_\_\_ 0.000\_час.  
 период t1-t2 < min (D) \_\_\_\_\_ 0.000\_час.  
 период G>max (G) \_\_\_\_\_ 0.000\_час.

Период функц. отказа (E) \_\_\_\_\_ 0.000\_час.  
 Период G<min (g) \_\_\_\_\_ 0.000\_час.

Представитель абонента \_\_\_\_\_ Представитель теплоснабжающей организации \_\_\_\_\_

