

Посуточная ведомость учета параметров теплопотребления  
 с 17.03.2023 по 17.04.2023

Дата	Q Гкал	Масса, тонн. Объем, м3					Температура, °С			Давление		Время, час		Классиф ошибок	
		M1	V1	M2	V2	M1-M2 разбор	t1	t2	t1-t2 tхв	P1 атм	P2 атм	Нераб. Тн	Работы Тр		
17.03.23	3.824	502.60	512.2344	492.08	499.6875	10.32	64.9	57.5	7.5	0.0	11.7	4.1	0.00	24.00	
18.03.23	3.846	500.73	510.3242	490.36	497.9063	10.38	64.9	57.4	7.5	0.0	11.7	4.1	0.00	24.00	
19.03.23	3.821	500.46	510.0430	490.07	497.6133	10.39	64.9	57.4	7.5	0.0	11.7	4.1	0.00	24.00	
20.03.23	3.794	503.11	512.7205	492.68	500.3047	10.43	64.9	57.5	7.4	0.0	11.7	4.1	0.00	24.00	
21.03.23	3.705	505.77	515.4570	495.38	503.1055	10.39	64.9	57.7	7.2	0.0	11.7	4.1	0.00	24.00	
22.03.23	3.668	506.75	516.4609	496.32	504.0859	10.43	64.9	57.8	7.1	0.0	11.7	4.1	0.00	24.00	
23.03.23	3.611	506.39	516.0820	495.91	503.6953	10.48	64.9	57.9	7.0	0.0	11.7	4.1	0.00	24.00	
24.03.23	3.574	505.11	514.7852	494.86	502.6328	10.25	64.9	58.0	6.9	0.0	11.7	4.1	0.00	24.00	
25.03.23	3.473	503.54	513.0078	493.18	500.8086	10.36	64.2	57.4	6.7	0.0	11.7	4.1	0.01	23.99	U
26.03.23	3.550	504.81	514.4961	494.48	502.2852	10.32	65.0	58.1	6.9	0.0	11.7	4.1	0.00	24.00	
27.03.23	3.572	501.86	511.4805	491.59	499.3320	10.27	65.0	58.0	7.0	0.0	11.7	4.1	0.00	24.00	
28.03.23	3.648	512.14	521.9648	501.68	509.5703	10.46	65.0	58.0	7.0	0.0	11.7	4.1	0.00	24.00	
29.03.23	3.667	515.25	525.1250	504.64	512.5703	10.61	65.0	58.0	7.0	0.0	11.7	4.1	0.00	24.00	
30.03.23	3.676	514.09	523.9375	503.48	511.3867	10.61	65.0	58.0	7.0	0.0	11.7	4.1	0.00	24.00	
31.03.23	3.777	511.57	521.3633	500.84	508.6484	10.72	64.9	57.7	7.2	0.0	11.7	4.1	0.00	24.00	
01.04.23	3.760	513.14	522.9883	502.50	510.3438	10.64	65.0	57.8	7.2	0.0	11.7	4.1	0.00	24.00	
02.04.23	3.647	513.90	523.7773	503.39	511.3047	10.51	65.0	58.0	6.9	0.0	11.7	4.1	0.00	24.00	
03.04.23	3.568	518.76	528.7227	508.29	516.3672	10.47	65.0	58.3	6.7	0.0	11.7	4.1	0.00	24.00	
04.04.23	3.497	522.50	532.5273	512.05	520.1392	10.45	65.0	58.4	6.5	0.0	11.7	4.1	0.00	24.00	
05.04.23	3.478	523.40	533.4297	512.84	521.0352	10.55	65.0	58.5	6.5	0.0	11.7	4.1	0.00	24.00	
06.04.23	3.490	524.94	535.0078	514.16	522.3633	10.78	65.0	58.5	6.5	0.0	11.7	4.1	0.00	24.00	
07.04.23	3.540	529.02	539.1602	518.11	526.3594	10.91	65.0	58.4	6.5	0.0	11.7	4.1	0.00	24.00	
08.04.23	3.547	531.99	542.1992	521.17	529.4844	10.82	65.0	58.5	6.5	0.0	11.7	4.1	0.00	24.00	
09.04.23	3.490	532.12	542.3281	521.50	529.4555	10.63	65.0	58.6	6.4	0.0	11.7	4.1	0.00	24.00	
10.04.23	3.481	528.80	538.9570	518.33	526.6328	10.46	65.0	58.5	6.4	0.0	11.7	4.0	0.00	24.00	
11.04.23	3.449	539.60	549.9570	528.92	537.4336	10.68	65.0	58.7	6.2	0.0	11.7	4.1	0.00	24.00	
12.04.23	3.425	538.07	548.3906	527.43	535.9297	10.64	65.0	58.8	6.2	0.0	11.7	4.1	0.00	24.00	
13.04.23	3.456	539.08	549.4219	528.03	536.5156	11.05	65.0	58.7	6.3	0.0	11.7	4.1	0.00	24.00	
14.04.23	3.592	537.75	548.0508	526.60	534.9961	11.16	65.0	58.4	6.5	0.0	11.7	4.1	0.00	24.00	
15.04.23	3.664	536.73	547.0234	525.63	533.9688	11.11	64.9	58.3	6.7	0.0	11.7	4.1	0.00	24.00	
16.04.23	3.597	536.88	547.1680	526.05	534.4414	10.82	65.0	58.4	6.6	0.0	11.7	4.1	0.00	24.00	
17.04.23	3.510	537.91	548.2227	527.17	535.6094	10.74	65.0	58.6	6.4	0.0	11.7	4.1	0.00	24.00	
Итого	115.397	16598.7	16916.8242	16259.7	16316.4727	339.04	64.9	58.1	6.8	0.0	11.7	4.1	0.01	767.99	0.01

лермонта 3/

Дата	Время	Q	M1	M2	V1	V2	Tr
17.04.23	24:00	426.474	53304.96	52193.13	54355.68	53014.92	2567.98
17.03.23	00:00	311.077	36706.18	35933.39	37438.86	36498.45	1799.99
Итого		115.397	16598.77	16259.74	16916.82	16516.47	767.99

Отчетный период — 768.00\_час.      период норм. работы — 767.99\_час.

период отключения питания (U) — 0.011\_час.      период функц.отказа (E) — 0.000\_час.  
 период t2-t1 < min (D) — 0.000\_час.      период G<min (g) — 0.000\_час.  
 период G>max (G) — 0.000\_час.



представитель абонента \_\_\_\_\_ Представитель теплоснабжающей организации \_\_\_\_\_

*Q = 115,399 Гкал*

