

Гпод.: 0.06 - 60.0 м3/ч Ду= мм

Гобр.: 0.06 - 60.0 м3/ч Ду= мм

Гп : 10 л/мм

Посуточная ведомость учета параметров теплоснабжения
с 17.03.2023 по 17.04.2023

Дата	Q Гкал	Масса, тонн. Объем, м3				Температура, °C				Давление		Время, час		Классиф ошибок
		M1	V1	M2	V2	M1-M2 разбор	t1	t2	t1-t2 tкв	P1 атм	P2 атм	Нераб. Тн	Работы Тр	
17.03.23	2.503	396.49	404.1914	393.26	399.5820	3.24	65.0	58.7	6.3	5.6	4.3	0.00	24.00	
18.03.23	2.516	393.18	400.8125	389.97	396.2402	3.21	65.0	58.6	6.4	5.6	4.3	0.00	24.00	
19.03.23	2.534	392.66	400.2676	389.44	395.6719	3.22	65.0	58.5	6.4	5.6	4.3	0.00	24.00	
20.03.23	2.514	396.28	403.9688	393.05	399.3633	3.22	65.0	58.7	6.3	5.6	4.3	0.00	24.00	
21.03.23	2.464	399.97	407.7207	396.72	403.1309	3.24	65.0	58.8	6.1	5.6	4.3	0.00	24.00	
22.03.23	2.393	398.90	406.6426	395.62	402.0488	3.28	65.0	59.0	6.0	5.6	4.3	0.00	24.00	
23.03.23	2.358	399.30	407.0449	396.00	402.4531	3.29	65.0	59.1	5.9	5.6	4.3	0.00	24.00	
24.03.23	2.306	398.00	405.7148	394.68	401.1270	3.32	65.0	59.2	5.8	5.6	4.3	0.00	24.00	
25.03.23	2.236	394.44	401.9414	391.11	397.3848	3.34	64.3	58.6	5.6	5.6	4.3	0.00	24.00	
26.03.23	2.309	397.49	403.2148	394.14	400.5957	3.35	65.0	59.3	5.8	5.6	4.3	0.00	24.00	
27.03.23	2.348	395.26	402.9336	391.93	398.3242	3.33	65.0	59.1	5.9	5.6	4.3	0.00	24.00	
28.03.23	2.348	402.39	410.2031	399.05	405.5938	3.34	65.1	59.2	5.8	5.7	4.3	0.00	24.00	
29.03.23	2.352	405.63	413.5000	402.29	408.8750	3.34	65.0	59.3	5.8	5.7	4.3	0.00	24.00	
30.03.23	2.397	404.81	412.6836	401.48	408.0273	3.34	65.1	59.2	5.9	5.7	4.3	0.00	24.00	
31.03.23	2.427	400.89	408.6836	397.57	404.0234	3.33	65.0	59.0	6.0	5.7	4.3	0.00	24.00	
01.04.23	2.398	403.26	411.0781	399.93	406.4297	3.34	65.0	59.1	5.9	5.7	4.3	0.00	24.00	
02.04.23	2.361	404.27	412.1367	400.92	407.4648	3.35	65.1	59.2	5.8	5.7	4.3	0.00	24.00	
03.04.23	2.354	410.38	418.3633	406.91	413.6016	3.47	65.1	59.4	5.7	5.7	4.3	0.00	24.00	
04.04.23	2.283	411.96	419.9727	408.48	415.2305	3.48	65.1	59.6	5.5	5.7	4.3	0.00	24.00	
05.04.23	2.263	412.35	420.3672	408.85	415.6094	3.50	65.1	59.6	5.5	5.7	4.3	0.00	24.00	
06.04.23	2.250	412.11	420.1172	408.59	415.3633	3.52	65.1	59.6	5.5	5.7	4.3	0.00	24.00	
07.04.23	2.310	416.92	425.0352	413.38	420.2031	3.55	65.1	59.6	5.5	5.8	4.3	0.00	24.00	
08.04.23	2.322	419.54	427.7031	415.95	422.8125	3.59	65.1	59.6	5.5	5.8	4.3	0.00	24.00	
09.04.23	2.295	419.44	427.5781	415.80	422.6836	3.64	65.1	59.6	5.5	5.8	4.3	0.00	24.00	
10.04.23	2.310	421.29	429.4531	417.67	424.5898	3.62	65.1	59.6	5.5	5.8	4.3	0.00	24.00	
11.04.23	2.295	429.83	438.1797	426.05	433.1445	3.78	65.1	59.8	5.3	5.9	4.3	0.00	24.00	
12.04.23	2.249	427.57	435.8906	423.80	430.8711	3.77	65.1	59.8	5.2	5.9	4.3	0.00	24.00	
13.04.23	2.241	427.48	435.7852	423.63	430.6836	3.86	65.1	59.8	5.2	5.9	4.3	0.00	24.00	
14.04.23	2.307	426.35	434.6328	422.55	429.5625	3.80	65.0	59.7	5.4	5.9	4.3	0.00	24.00	
15.04.23	2.339	424.61	432.8594	420.83	427.7813	3.78	65.0	59.5	5.5	5.9	4.3	0.00	24.00	
16.04.23	2.360	427.44	435.7339	423.65	430.6523	3.79	65.0	59.5	5.5	5.9	4.3	0.00	24.00	
17.04.23	2.295	427.14	435.4258	423.33	430.3594	3.82	65.0	59.7	5.3	5.9	4.3	0.00	24.00	
Итого	75.238	13097.6	13351.8555	12986.6	13199.4844	111.02	65.0	59.3	5.7	5.7	4.3	0.00	768.00	0.00

Иркутск, 19.01

Дата время	Q	M1	M2	V1	V2	Tr
17.04.23 24:00	278.431	41719.53	41388.78	42552.49	42067.71	2568.00
17.03.23 00:00	203.192	28621.89	28402.16	29200.64	28868.23	1800.00
Итого	75.238	13097.63	12986.62	13351.86	13199.48	768.00

Отчетный период _____ 768.00_час. Период норм. работы _____ 768.00_час.

Период отключения питания (U) _____ 0.000_час.
Период t2-t1 < min (D) _____ 0.000_час.
Период G>max (G) _____ 0.000_час.



Представитель абонента _____

Представитель теплоснабжающей организации _____

[Handwritten signature]

