

Посуточная ведомость учета параметров теплопотребления
с 17.03.2023 по 17.04.2023

Дата	Q Гкал	Масса, тонн				V2	Температура, °C				Давление		Время, час		Классиф ошибок
		M1	V1	M2	V2		M1-M2 разбор	t1	t2	t1-t2	txv	P1 атм	P2 атм	Нераб. ТН	
17.03.23	3.454	116.76	119.4131	115.34	116.3047	1.42	71.1	41.6	29.5	0.0	11.9	6.8	0.00	24.00	
18.03.23	3.830	135.54	138.6455	134.08	139.2852	1.46	71.4	43.3	28.2	0.0	11.9	6.8	0.00	24.00	
19.03.23	3.873	140.28	143.4561	138.72	139.9883	1.55	71.1	43.6	27.5	0.0	11.9	6.8	0.00	24.00	
20.03.23	3.519	122.64	125.4131	121.25	122.2979	1.39	71.0	42.4	28.6	0.0	11.9	6.8	0.00	24.00	
21.03.23	2.875	91.84	93.6094	90.25	90.9365	1.29	71.1	39.7	31.3	0.0	11.9	6.8	0.00	24.00	
22.03.23	2.743	86.04	87.9717	84.76	85.3779	1.28	70.7	38.9	31.8	0.0	11.9	6.8	0.00	24.00	
23.03.23	2.459	83.54	85.2666	82.30	82.8789	1.24	67.3	38.0	29.4	0.0	11.9	6.8	0.00	24.00	
24.03.23	2.382	71.99	73.5967	70.87	71.3477	1.12	70.6	37.5	33.0	0.0	11.9	6.8	0.00	24.00	
25.03.23	2.268	68.82	70.4494	67.64	68.1006	0.98	70.7	37.7	33.0	0.0	11.9	6.8	0.45	23.55	
26.03.23	2.403	73.00	74.6309	71.95	72.4502	1.05	70.6	37.7	32.9	0.0	11.9	6.8	0.00	24.00	
27.03.23	2.664	83.96	85.8389	82.87	83.4766	1.09	70.6	38.9	31.7	0.0	11.9	6.8	0.00	24.00	
28.03.23	2.661	83.39	85.2803	82.27	82.8828	1.13	71.0	39.2	31.8	0.0	11.9	6.8	0.00	24.00	
29.03.23	2.535	76.86	78.5947	75.78	76.3115	1.08	70.9	38.0	32.9	0.0	11.9	6.8	0.00	24.00	
30.03.23	3.111	102.67	104.9766	101.43	102.2275	1.24	70.7	40.5	30.2	0.0	11.9	6.8	0.00	24.00	
31.03.23	3.637	133.80	136.7422	132.37	133.5352	1.43	69.8	42.7	27.1	0.0	11.9	6.8	0.00	24.00	
01.04.23	3.072	102.23	104.4150	100.86	101.6599	1.26	70.6	40.6	30.0	0.0	11.9	6.8	0.00	24.00	
02.04.23	2.382	72.75	74.3584	71.74	72.2305	1.00	70.2	37.5	32.7	0.0	11.9	6.8	0.00	24.00	
03.04.23	2.150	63.25	64.6592	62.34	62.7412	0.91	70.5	36.5	33.9	0.0	11.9	6.8	0.00	24.00	
04.04.23	2.104	62.85	64.2344	61.93	62.3262	0.92	70.0	36.5	33.4	0.0	11.9	6.8	0.00	24.00	
05.04.23	2.058	61.45	62.8037	60.54	60.9768	0.92	70.0	36.5	33.4	0.0	11.9	6.8	0.00	24.00	
06.04.23	2.177	65.90	67.3584	64.94	65.3691	0.96	70.1	37.2	33.0	0.0	11.9	6.8	0.00	24.00	
07.04.23	2.417	74.30	75.9648	73.24	73.7656	1.06	70.6	38.2	32.5	0.0	11.9	6.8	0.00	24.00	
08.04.23	2.392	73.58	75.2246	72.51	73.0254	1.07	70.6	38.2	32.5	0.0	11.9	6.8	0.00	24.00	
09.04.23	2.125	62.48	63.8828	61.49	61.8984	0.99	70.7	36.8	34.0	0.0	11.9	6.8	0.00	24.00	
10.04.23	2.154	64.64	66.0723	63.62	64.0381	1.02	70.3	37.0	33.3	0.0	11.9	6.8	0.00	24.00	
11.04.23	1.916	54.81	56.0410	53.86	54.2021	0.95	70.8	35.9	34.9	0.0	11.9	6.8	0.00	24.00	
12.04.23	1.729	52.95	54.0977	49.68	50.0117	3.26	69.5	36.9	32.6	0.0	11.9	6.8	0.00	24.00	
13.04.23	1.654	48.68	49.7402	46.03	46.3223	2.65	69.7	35.8	33.9	0.0	11.9	6.8	0.00	24.00	
14.04.23	2.578	84.63	86.4629	83.47	84.0869	1.15	69.6	39.2	30.4	0.0	11.9	6.8	0.00	24.00	
15.04.23	2.887	97.20	99.3457	95.90	96.6602	1.29	70.1	40.4	29.6	0.0	11.9	6.8	0.00	24.00	
16.04.23	2.889	75.07	76.7344	73.96	74.4922	1.11	70.2	38.4	31.8	0.0	11.9	6.8	0.00	24.00	
17.04.23	2.020	59.06	60.3691	58.09	58.4609	0.97	70.3	36.2	34.1	0.0	11.9	6.8	0.00	24.00	
Итого	82.619	2646.34	2705.3496	2606.09	2625.6289	40.25	70.5	39.3	31.2	0.0	11.9	6.8	0.45	767.55	0.45

Дата	Время	Q	M1	M2	V1	V2	Tr
17.04.23	24:00	435.873	16706.69	16499.94	17096.22	16669.13	2565.89
17.03.23	00:00	353.254	14060.36	13893.85	14390.87	14043.50	1798.34
Итого		82.619	2646.34	2606.09	2705.35	2625.63	767.55

Отчетный период _____768.00_час. период норм. работы _____767.55_час.
 период отключения питания (U) _____0.451_час. период функц. отказа: (E) _____0.000_час.
 период t2-t1 < min (D) _____0.000_час. период G<min (G) _____0.000_час.
 период G>max (G) _____0.000_час.



Представитель абонента _____
 Представитель теплоснабжающей организации _____

Q = 82,667 т/час

