

Глод.: 0.06 - 60.0 м3/ч Ду= мм
 Гобр.: 0.06 - 60.0 м3/ч Ду= мм
 Гп : 10 л/Имп

Посуточная ведомость учета параметров теплопотребления
 с 17.12.2022 по 16.01.2023

Дата	Q Гкал	Масса, тонн. Объем, м3			Температура, °С			Давление		Время, час		классиф ошибок		
		M1	V1	M2	V2	M1-M2 разбор	t1	t2	t1-t2 tхв	P1 атм	P2 атм		нераб. Тн	работ Тр
17.12.22	1.844	163.48	166.5820	147.39	149.7461	16.09	64.4	58.1	6.3	9.0	9.0	0.4	0.00	24.00
18.12.22	2.001	166.26	169.3594	146.99	149.3008	19.27	63.8	57.6	6.3	9.0	9.0	0.4	0.00	24.00
19.12.22	1.794	162.63	165.7109	147.86	150.2227	14.77	64.4	58.0	6.4	9.0	9.0	0.4	0.00	24.00
20.12.22	1.848	163.55	166.6367	147.56	149.9023	15.99	64.2	57.9	6.4	9.0	9.0	0.4	0.00	24.00
21.12.22	1.914	164.37	167.5313	147.44	149.8242	16.93	64.9	58.5	6.4	9.0	9.0	0.4	0.00	24.00
22.12.22	1.935	164.64	167.8477	147.54	149.9570	17.11	65.3	58.9	6.4	9.0	9.0	0.4	0.00	24.00
23.12.22	1.800	162.94	166.0898	148.00	150.4375	14.93	65.1	58.7	6.3	9.0	9.0	0.4	0.00	24.00
24.12.22	1.962	165.85	169.0273	147.73	150.1250	18.12	64.8	58.4	6.3	9.0	9.0	0.4	0.00	24.00
25.12.22	1.973	165.47	168.6445	147.30	149.6719	18.37	64.5	58.2	6.2	9.0	9.0	0.4	0.00	24.00
26.12.22	1.966	166.02	169.1680	147.63	150.0156	18.37	64.4	58.1	6.3	9.0	9.0	0.4	0.00	24.00
27.12.22	1.877	164.39	167.5078	147.73	150.1094	16.66	64.4	58.6	6.4	9.0	9.0	0.4	0.00	24.00
28.12.22	1.912	164.62	167.7930	147.67	150.0781	16.95	65.0	58.6	6.4	9.0	9.0	0.4	0.00	24.00
29.12.22	1.839	163.82	166.9336	147.81	150.2109	16.01	64.6	58.3	6.2	9.0	9.0	0.4	0.00	24.00
30.12.22	2.115	168.24	171.4727	147.18	149.5703	21.07	64.9	58.7	6.2	9.0	9.0	0.4	0.00	24.00
31.12.22	2.325	171.44	174.6602	145.27	147.8984	25.87	64.1	58.1	6.0	9.0	9.0	0.4	0.00	24.00
01.01.23	1.734	162.25	165.3978	148.62	151.0615	13.63	65.2	58.9	6.3	9.0	9.0	0.4	0.00	24.00
02.01.23	1.851	164.25	167.3549	148.01	150.3679	16.25	64.3	58.0	6.3	9.0	9.0	0.4	0.00	24.00
03.01.23	1.833	163.47	166.6092	147.84	150.2354	15.63	64.8	58.5	6.3	9.0	9.0	0.4	0.00	24.00
04.01.23	1.880	162.76	166.6229	147.77	150.1291	15.76	64.7	58.3	6.4	9.0	9.0	0.4	0.00	24.00
05.01.23	2.147	161.15	165.8896	145.88	148.5693	16.54	64.3	58.3	6.4	9.0	9.0	0.4	0.01	23.99
06.01.23	2.221	160.72	164.7286	145.85	148.6688	15.27	71.8	63.8	8.0	9.0	9.0	0.4	0.00	24.00
07.01.23	2.370	165.96	169.6155	144.24	148.9403	21.88	69.7	62.6	7.1	9.0	9.0	0.4	0.00	24.00
08.01.23	2.025	163.55	166.9495	145.24	149.7953	16.31	67.7	60.6	7.1	9.0	9.0	0.4	0.00	24.00
09.01.23	1.960	164.26	167.2877	145.23	147.4900	19.03	63.4	57.2	6.2	9.0	9.0	0.4	0.00	24.00
10.01.23	2.034	163.50	166.8542	145.39	147.7301	18.11	63.1	58.2	6.8	9.0	9.0	0.4	0.00	24.00
11.01.23	2.052	163.64	166.8542	145.22	147.6067	18.42	65.7	58.9	6.8	9.0	9.0	0.4	0.00	24.00
12.01.23	1.995	163.21	166.4418	145.88	148.2992	17.33	65.9	59.2	6.7	9.0	9.0	0.4	0.00	24.00
13.01.23	2.021	163.73	166.9814	145.91	148.3391	17.82	66.1	59.3	6.7	9.0	9.0	0.4	0.00	24.00
14.01.23	2.165	166.03	169.3079	145.29	147.6973	20.74	65.8	59.2	6.6	9.0	9.0	0.4	0.00	24.00
15.01.23	2.064	164.63	167.8564	145.61	148.0061	19.02	65.6	59.0	6.6	9.0	9.0	0.4	0.00	24.00
16.01.23														
Итого	61.288	5094.37	5194.3945	4551.66	4626.8423	542.71	65.6	59.1	6.6	9.0	9.0	0.4	0.01	743.99

16.1.23 24:00 01.01.23 00:00 31.12.22 24:00 17.12.22 00:00

Дата	Время	Q	M1	M2	V1	V2	Tr
16.01.23	24:00	32.183	2616.64	2340.23	2669.43	2379.77	383.99
01.01.23	00:00	0.000	0.00	0.00	0.00	0.00	0.00
31.12.22	24:00	622.538	58837.72	53405.13	59947.97	54263.13	8463.74
17.12.22	00:00	593.432	56359.99	51193.70	57423.01	52016.06	8103.74
Итого		61.288	5094.37	4551.66	5194.39	4626.84	743.99

Исчисленный период — 744.00_час. Период норм. работы — 743.99_час.

Период отключения питания (U) — 0.000_час. Период функц. отказа (E) — 0.007_час.
 Период t2-t1 < min (D) — 0.000_час. Период G<min (G) — 0.000_час.

Представитель абонента

(Signature)

Представитель теллоснабжающей организации

(Signature)

Vтмс. = 567,558 кв.ч
90%
Qтмс. = 35,416 кв.ч
9

