

УИЧО. Соловьев

УИЧО. Соловьев
 Номер договора _____
 Телефон _____
 Номер теплосчетчика 363770
 Спод.: 0.06 - 60.0 м3/ч ДУ= _____ мм
 Собр.: 0.06 - 60.0 м3/ч ДУ= _____ мм
 Гр : 10 л/МВт

Посуточная ведомость учета параметров теплопотребления
 с 17.12.2022 по 16.01.2023
601.01.23

Дата	Q Гкал	Масса, тонн. Объем, м3				Температура, °C				Давление		Время, час		Классиф ошибок	
		M1	V1	M2	V2	M1-M2 разбор	t1	t2	t1-t2	txv	P1 атм	P2 атм	Нераб. Тн		Работы Тр
17.12.22	0.810	80.64	82.4609	81.20	82.5898	-0.56	70.6	60.6	10.0	0.0	5.5	4.3	24.00	10.06	U
22.12.22	1.905	193.70	198.0508	195.07	198.3906	-1.38	70.4	60.5	9.8	0.0	5.5	4.3	24.00	24.00	U
18.12.22	1.882	194.05	198.4180	195.40	198.7344	-1.34	70.3	60.6	9.7	0.0	5.5	4.2	24.00	24.00	U
19.12.22	1.885	187.48	191.7344	188.79	192.0039	-1.30	70.6	60.6	10.0	0.0	5.4	4.2	24.00	24.00	U
25.12.22	1.911	186.44	190.6250	187.76	190.9180	-1.32	70.3	60.1	10.2	0.0	5.4	4.3	24.00	24.00	U
26.12.22	1.915	188.19	192.3984	189.48	192.6680	-1.29	70.2	60.0	10.2	0.0	5.5	4.3	24.00	24.00	U
27.12.22	1.900	191.32	195.6211	192.66	195.9570	-1.34	70.4	60.5	9.9	0.0	5.5	4.3	24.00	24.00	U
28.12.22	1.871	189.82	194.0703	191.20	194.4375	-1.38	70.1	60.2	9.8	0.0	5.5	4.3	24.00	24.00	U
29.12.22	1.888	194.19	198.5625	195.59	198.9297	-1.40	70.4	60.7	9.7	0.0	5.5	4.3	24.00	24.00	U
30.12.22	1.867	194.46	198.8281	195.89	199.2227	-1.42	70.1	60.6	9.6	0.0	5.5	4.3	24.00	24.00	U
01.01.23	1.872	201.45	203.9642	202.91	206.4108	-1.46	70.2	61.0	9.3	0.0	5.7	4.3	24.00	24.00	U
02.01.23	1.809	196.39	200.6952	197.83	201.1672	-1.44	69.4	60.8	9.2	0.0	5.6	4.3	24.00	24.00	U
03.01.23	1.853	199.44	203.8853	200.89	204.3370	-1.45	70.0	60.8	9.3	0.0	5.7	4.3	24.00	24.00	U
04.01.23	1.853	195.11	199.4277	196.51	199.8303	-1.40	69.7	60.2	9.5	0.0	5.6	4.3	24.00	24.00	U
05.01.23	1.898	191.92	196.2215	193.30	196.5703	-1.38	70.2	60.3	9.9	0.0	5.5	4.3	24.00	24.00	U
06.01.23	2.524	186.59	192.0642	187.92	191.8622	-1.33	81.1	67.6	13.5	0.0	5.4	4.3	24.00	24.00	U
07.01.23	2.757	186.72	192.6510	188.08	192.2821	-1.36	84.7	70.0	14.7	0.0	5.4	4.3	24.00	24.00	U
08.01.23	2.681	188.98	194.7291	190.38	194.4773	-1.40	82.7	68.6	14.2	0.0	5.5	4.3	24.00	24.00	U
09.01.23	2.676	191.99	197.8025	193.40	197.5630	-1.40	82.5	68.6	13.9	0.0	5.5	4.3	24.00	24.00	U
10.01.23	2.379	189.20	194.1851	190.52	194.1304	-1.32	76.5	64.0	12.5	0.0	5.5	4.3	24.00	24.00	U
11.01.23	2.245	183.23	187.7242	184.53	187.7654	-1.30	73.7	61.4	12.2	0.0	5.4	4.3	24.00	24.00	U
12.01.23	2.131	179.41	183.5852	180.66	183.6626	-1.25	71.6	59.7	11.9	0.0	5.3	4.3	24.00	24.00	U
13.01.23	2.108	184.86	189.1504	186.18	189.3132	-1.32	71.6	60.2	11.4	0.0	5.4	4.3	24.00	24.00	U
14.01.23	2.059	190.65	195.0522	192.01	195.2874	-1.36	71.4	60.6	10.8	0.0	5.5	4.3	24.00	24.00	U
15.01.23	2.031	191.42	195.8379	192.78	196.0862	-1.36	71.4	60.8	10.6	0.0	5.5	4.3	24.00	24.00	U
16.01.23	2.028	188.03	192.3472	189.36	192.5667	-1.33	71.1	60.4	10.8	0.0	5.5	4.3	24.00	24.00	U
Итого	52.741	4845.70	4962.0928	4880.30	4967.1636	-34.61	72.8	61.9	10.9	0.0	5.5	4.3	133.94	610.06	133.94

показания интeграторов км-5
 34,907

Дата	Время	Q	M1	M2	V1	V2	Тр
16.01.23	24:00	34.905	3045.40	3067.26	3121.32	3123.31	384.00
17.01.23	00:00	0.000	0.00	0.00	0.00	0.00	0.00
17.01.23	24:00	387.148	40419.80	40717.30	41335.58	41472.64	8367.71
17.12.22	00:00	369.312	38619.50	38904.26	39494.81	39578.79	8141.65
Итого		52.741	4845.70	4880.30	4962.09	4967.16	610.06

Итого: период — 744.00_час. Период норм. работы — 610.06_час.

период отключения питания (U) — 133.939_час.
 период t2-t1 < min (D) — 0.000_час.
 период G>max (G) — 0.000_час.

период функц. отказа (E) — 0.000_час.
 период G<min (G) — 0.000_час.

Представитель
 клиента

Представитель
 теплоснабжающей
 организации



Дата: 16.01.23 г. № 16.01.23

Период расчета с 01.01.23 по 16.01.23 Q=34907ГД