

Организация "ООО "Управдом ЮГ Подмосковья" \_\_\_\_\_ Номер Договора \_\_\_\_\_  
 Адрес "Московское шоссе, д.38" \_\_\_\_\_ Телефон \_\_\_\_\_  
 Тип теплосчетчика "КМ-5-2" \_\_\_\_\_ Версия "02.30" \_\_\_\_\_ Номер теплосчетчика "381482"  
 Дата последней поверки теплосчетчика \_\_\_\_\_

Год.: 0.1 - 100.0м3/ч Ду= \_\_\_\_\_ мм  
 Гобр.: 0.1 - 100.0м3/ч Ду= \_\_\_\_\_ мм  
 Гп : 10 \_\_\_\_\_ л/Имп

Посуточная ведомость учета параметров теплоснабжения  
 с "22.01.2024" по "18.02.2024"

| Дата     | Q     | M1     | V1       | M2     | V2       | M1-M2 | t1   | t2   | t1-t2 | хв  | P1     | P2  | Нераб. | Работы | Классиф |
|----------|-------|--------|----------|--------|----------|-------|------|------|-------|-----|--------|-----|--------|--------|---------|
|          | Гкал  |        |          | разбор |          |       | атм  | атм  | Тн    | Тр  | ошибок |     |        |        |         |
| 22.01.24 | 4.241 | 196.86 | 201.1177 | 195.42 | 197.5574 | 1.44  | 69.0 | 47.6 | 21.4  | 0.0 | 7.0    | 0.1 | 0.00   | 24.00  |         |
| 23.01.24 | 3.937 | 196.58 | 200.4912 | 195.15 | 197.1541 | 1.43  | 66.0 | 46.1 | 19.9  | 0.0 | 7.0    | 0.1 | 0.00   | 24.00  |         |
| 24.01.24 | 3.524 | 197.78 | 201.2788 | 196.32 | 198.1812 | 1.46  | 61.9 | 44.2 | 17.7  | 0.0 | 7.2    | 0.1 | 0.00   | 24.00  |         |
| 25.01.24 | 3.164 | 197.93 | 201.0630 | 196.50 | 198.2261 | 1.43  | 58.4 | 42.5 | 15.9  | 0.0 | 7.2    | 0.1 | 0.00   | 24.00  |         |
| 26.01.24 | 3.218 | 197.82 | 201.0020 | 196.37 | 198.1187 | 1.44  | 58.9 | 42.8 | 16.1  | 0.0 | 7.1    | 0.1 | 0.00   | 24.00  |         |
| 27.01.24 | 3.765 | 197.56 | 201.3462 | 196.13 | 198.1152 | 1.43  | 64.7 | 45.7 | 18.9  | 0.0 | 7.1    | 0.1 | 0.00   | 24.00  |         |
| 28.01.24 | 3.808 | 197.43 | 201.3193 | 195.98 | 198.0283 | 1.45  | 65.6 | 46.5 | 19.2  | 0.0 | 7.1    | 0.1 | 0.00   | 24.00  |         |
| 29.01.24 | 3.638 | 198.42 | 202.1538 | 197.01 | 199.0161 | 1.40  | 64.1 | 45.8 | 18.2  | 0.0 | 7.1    | 0.1 | 0.00   | 24.00  |         |
| 30.01.24 | 3.415 | 198.05 | 201.5337 | 196.74 | 198.6416 | 1.31  | 61.8 | 44.6 | 17.1  | 0.0 | 7.2    | 0.1 | 0.00   | 24.00  |         |
| 31.01.24 | 3.334 | 198.40 | 201.8208 | 196.98 | 198.8662 | 1.42  | 61.1 | 44.4 | 16.7  | 0.0 | 7.2    | 0.1 | 0.00   | 24.00  |         |
| 01.02.24 | 3.269 | 198.11 | 201.4858 | 196.66 | 198.5278 | 1.46  | 60.7 | 44.3 | 16.4  | 0.0 | 7.2    | 0.1 | 0.00   | 24.00  |         |
| 02.02.24 | 3.297 | 197.70 | 201.1128 | 196.26 | 198.1450 | 1.45  | 61.1 | 44.6 | 16.6  | 0.0 | 7.0    | 0.1 | 0.00   | 24.00  |         |
| 03.02.24 | 3.382 | 197.71 | 201.2305 | 196.19 | 198.1270 | 1.52  | 62.2 | 45.2 | 17.0  | 0.0 | 6.8    | 0.1 | 0.00   | 24.00  |         |
| 04.02.24 | 3.047 | 197.90 | 201.0605 | 196.40 | 198.1885 | 1.50  | 58.7 | 43.4 | 15.3  | 0.0 | 6.8    | 0.1 | 0.00   | 24.00  |         |
| 05.02.24 | 3.129 | 197.66 | 200.8955 | 196.20 | 198.0117 | 1.47  | 59.4 | 43.7 | 15.7  | 0.0 | 6.8    | 0.1 | 0.00   | 24.00  |         |
| 06.02.24 | 3.393 | 197.06 | 200.5503 | 195.65 | 197.5581 | 1.41  | 61.9 | 44.8 | 17.1  | 0.0 | 6.8    | 0.1 | 0.00   | 24.00  |         |
| 07.02.24 | 3.758 | 200.03 | 203.9658 | 198.56 | 200.6655 | 1.47  | 65.6 | 46.9 | 18.7  | 0.0 | 6.7    | 0.1 | 0.00   | 24.00  |         |
| 08.02.24 | 4.118 | 197.49 | 201.7803 | 196.02 | 198.2383 | 1.47  | 69.2 | 48.4 | 20.7  | 0.0 | 6.7    | 0.1 | 0.00   | 24.00  |         |
| 09.02.24 | 4.221 | 197.23 | 201.6152 | 195.66 | 197.8994 | 1.57  | 70.0 | 48.7 | 21.3  | 0.0 | 6.7    | 0.1 | 0.00   | 24.00  |         |
| 10.02.24 | 4.242 | 197.30 | 201.6606 | 195.67 | 197.8823 | 1.63  | 69.8 | 48.4 | 21.4  | 0.0 | 6.7    | 0.1 | 0.00   | 24.00  |         |
| 11.02.24 | 4.116 | 196.68 | 200.8511 | 195.25 | 197.3745 | 1.43  | 68.3 | 47.5 | 20.8  | 0.0 | 6.7    | 0.1 | 0.00   | 24.00  |         |
| 12.02.24 | 3.539 | 196.71 | 200.2715 | 195.30 | 197.1963 | 1.42  | 62.7 | 44.8 | 17.9  | 0.0 | 6.7    | 0.1 | 0.00   | 24.00  |         |

-13 461

|          |         |         |          |            |          |         |       |      |      |     |     |     |      |        |
|----------|---------|---------|----------|------------|----------|---------|-------|------|------|-----|-----|-----|------|--------|
| 13.02.24 | 3.428   | 196.01  | 199.3936 | 194.56     | 196.3643 | 1.45    | 61.2  | 43.8 | 17.4 | 0.0 | 6.7 | 0.1 | 0.00 | 24.00  |
| 14.02.24 | 4.130   | 196.76  | 200.8877 | 195.26     | 197.3438 | 1.50    | 67.8  | 46.9 | 20.9 | 0.0 | 6.7 | 0.1 | 0.00 | 24.00  |
| 15.02.24 | 4.178   | 196.84  | 201.0000 | 195.31     | 197.3965 | 1.53    | 68.2  | 47.0 | 21.1 | 0.0 | 6.7 | 0.1 | 0.00 | 24.00  |
| 16.02.24 | 4.069   | 196.68  | 200.7363 | 195.18     | 197.2334 | 1.50    | 67.2  | 46.6 | 20.6 | 0.0 | 6.7 | 0.1 | 0.00 | 24.00  |
| 17.02.24 | 3.694   | 196.81  | 200.4707 | 195.31     | 197.2236 | 1.49    | 63.6  | 44.9 | 18.7 | 0.0 | 6.7 | 0.1 | 0.00 | 24.00  |
| 18.02.24 | 3.310   | 196.70  | 199.9463 | 195.26     | 197.0166 | 1.43    | 59.7  | 43.0 | 16.7 | 0.0 | 6.7 | 0.1 | 0.00 | 24.00  |
| Итого    | 102.361 | 5528.20 | 5632.04  | 10410.5487 | 31.5542  | 2974.40 | 90.63 | 9.45 | 5.18 | 0.0 | 6.9 | 0.1 | 0.00 | 672.00 |

Показания интеграторов КМ-5

| Дата     | Время | Q       | M1      | M2      | V1      | V2      | Tr      |
|----------|-------|---------|---------|---------|---------|---------|---------|
| 18.02.24 | 24:00 | 189.536 | 9413.92 | 9344.15 | 9597.61 | 9436.51 | 1176.00 |
| 22.01.24 | 00:00 | 87.175  | 3885.71 | 3856.84 | 3965.57 | 3894.22 | 504.00  |
| Итого    |       | 102.361 | 5528.20 | 5487.31 | 5632.04 | 5542.30 | 672.00  |

Отчетный период \_\_\_\_\_ 672.00\_ час. Период норм. работы \_\_\_\_\_ 672.00\_ час.

Период отключения питания (U) \_\_\_\_\_ 0.000\_ час. Период функц.отказа (E) \_\_\_\_\_ 0.000\_ час.  
 Период t2-t1 < min (D) \_\_\_\_\_ 0.000\_ час. Период G>min (G) \_\_\_\_\_ 0.000\_ час.  
 Период G>max (G) \_\_\_\_\_ 0.000\_ час.

Представитель \_\_\_\_\_ Представитель теплоснабжающей  
 абонента \_\_\_\_\_ организации \_\_\_\_\_

