

Посуточная ведомость учета параметров теплоснабжения
 с 02.10.2024 по 18.10.2024

Дата	Q Гкал	Масса, тонн. Объем, м3				Температура, °C				Давление		Время, час		Классиф ошибок	
		M1	V1	M2	V2	M1-M2 разбор	t1	t2	t1-t2	tхв	P1 атм	P2 атм	Нераб. Тн		Работы Тр
02.10.24	0.277	53.15	53.8477	52.87	53.4434	0.28	51.6	46.5	5.1	0.0	2.0	-0.3	0.16	23.84	D
03.10.24	0.739	222.72	225.3223	222.28	224.5684	0.44	48.0	44.8	3.2	0.0	5.1	-0.3	0.00	24.00	
04.10.24	1.072	215.56	218.7598	215.31	218.0410	0.25	56.2	51.4	4.9	0.0	5.1	-0.3	0.00	24.00	
05.10.24	1.101	204.36	207.5000	204.16	206.8203	0.20	57.4	52.1	5.3	0.0	5.1	-0.3	0.00	24.00	
06.10.24	1.159	209.68	212.8105	209.45	212.0840	0.23	56.6	51.1	5.4	0.0	5.1	-0.3	0.00	24.00	
07.10.24	1.314	212.14	215.5156	211.45	214.2344	0.68	58.4	52.3	6.1	0.0	5.1	-0.3	0.00	24.00	
08.10.24	1.326	206.52	209.7754	206.38	209.0488	0.14	58.2	51.9	6.3	0.0	5.1	-0.3	0.00	24.00	
09.10.24	1.393	212.10	215.3555	211.92	214.5625	0.19	57.3	50.9	6.5	0.0	5.1	-0.3	0.00	24.00	
10.10.24	1.007	175.98	178.0293	175.86	177.5078	0.12	49.1	43.5	5.6	0.0	5.0	-0.3	0.30	23.70	D
11.10.24	0.817	165.11	166.5117	165.36	166.4609	-0.25	41.9	37.1	4.8	0.0	5.2	-0.3	0.00	24.00	
12.10.24	0.833	165.24	166.6348	165.47	166.5625	-0.23	41.8	36.8	4.9	0.0	5.1	-0.3	0.00	24.00	
13.10.24	0.955	174.38	175.9414	174.54	175.7500	-0.17	43.1	37.7	5.4	0.0	5.1	-0.3	0.00	24.00	
14.10.24	0.859	166.71	168.0586	166.88	167.9219	-0.17	41.0	35.9	5.1	0.0	4.9	-0.3	0.00	24.00	
15.10.24	1.363	160.98	162.9219	161.25	162.6211	-0.27	49.9	41.5	8.4	0.0	4.9	-0.3	0.00	24.00	
16.10.24	1.493	161.19	163.4414	161.48	163.0742	-0.29	54.4	45.2	9.2	0.0	4.9	-0.3	0.00	24.00	
17.10.24	1.615	160.01	162.3730	160.37	162.0195	-0.35	56.1	46.1	10.0	0.0	4.9	-0.3	0.00	24.00	
18.10.24	1.486	159.01	161.1914	159.36	160.9063	-0.34	54.0	44.7	9.3	0.0	4.9	-0.3	0.00	24.00	
Итого	18.808	3024.83	3063.9902	3024.37	3055.6270	0.46	51.9	45.8	6.1	0.0	4.9	-0.3	0.46	407.54	0.46

Тр = 407.54


Q = 18822.76 ккал

Z Q = 361806.7 ккал

Показания интеграторов КМ-5

Дата	Время	Q	M1	M2	V1	V2	Tr
18.10.24	24:00	231.583	22020.41	22046.90	22372.40	22290.63	6984.23
02.10.24	00:00	212.775	18995.58	19022.53	19308.41	19335.00	6576.69
Итого		18.808	3024.83	3024.37	3063.99	3055.63	407.54

Отчетный период: 408.00 час. Период норм. работы: 407.54 час.
 Период отключения питания (У): 0.000 час. Период функц. отказа (Е): 0.000 час.
 Период t2-t1 < min (D): 0.461 час. Период G<min (G): 0.000 час.



-3812