

Год. : _____ М3/ч Ду = _____ мм
 Год. : _____ М3/ч Ду = _____ мм
 ГП : _____ л/Имп


Посуточная ведомость учета параметров теплосчетчика с 18.12.2024 по 17.01.2025

Дата	Q Гкал	M1	Масса, тонн, Объем, м3			M1-M2 разбор	Температура, °C				Давление		Время, час		Классиф ошибок
			V1	M2	V2		t1	t2	t1-t2	tхв	P1 атм	P2 атм	Нераб. Тн	Работы Тр	
18.12.24	2.773	151.11	154.7598	147.91	149.9375	3.19	72.4	53.9	18.5	0.0	-0.0	5.0	0.00	24.00	
19.12.24	2.644	151.04	154.5137	147.84	149.7715	3.21	70.3	52.7	17.6	0.0	-0.1	5.0	0.00	24.00	
20.12.24	1.700	151.23	153.4512	147.92	149.3066	3.31	55.5	44.1	11.4	0.0	-0.0	5.0	0.00	24.00	
21.12.24	1.819	151.58	153.9512	148.28	149.7266	3.30	57.3	45.2	12.1	0.0	-0.1	5.0	0.00	24.00	
22.12.24	2.008	151.45	154.1035	148.19	149.7734	3.26	60.9	47.5	13.4	0.0	-0.1	5.0	0.00	24.00	
23.12.24	1.869	151.37	153.8574	148.09	149.6074	3.28	58.9	46.4	12.5	0.0	-0.1	5.0	0.00	24.00	
24.12.24	1.776	151.51	153.8535	148.19	149.6429	3.32	57.1	45.2	11.8	0.0	-0.1	5.0	0.00	24.00	
25.12.24	1.895	151.23	153.7051	147.96	149.4629	3.27	58.8	46.2	12.6	0.0	-0.1	5.0	0.00	24.00	
26.12.24	1.897	151.16	153.6484	147.90	149.4141	3.26	59.0	46.3	12.7	0.0	-0.1	5.0	0.00	24.00	
27.12.24	1.882	151.23	153.7051	147.98	149.4766	3.26	58.7	46.1	12.6	0.0	-0.1	5.0	0.00	24.00	
28.12.24	1.904	151.21	153.7031	147.93	149.4434	3.28	59.0	46.3	12.7	0.0	-0.1	5.0	0.00	24.00	
29.12.24	1.847	151.21	153.6973	147.93	149.4160	3.27	58.1	45.8	12.3	0.0	-0.1	5.0	0.00	24.00	
30.12.24	1.922	151.18	153.6309	147.90	149.4297	3.27	58.1	45.8	12.3	0.0	-0.1	5.0	0.00	24.00	
31.12.24	1.822	151.23	153.6289	147.94	149.4199	3.29	57.8	45.6	12.2	0.0	-0.0	5.0	0.00	24.00	
01.01.25	1.877	151.03	153.5031	147.74	149.2419	3.29	58.7	46.1	12.5	0.0	-0.0	5.0	0.00	24.00	
02.01.25	1.703	151.12	153.3539	147.83	149.1386	3.30	59.8	46.8	13.0	0.0	-0.0	5.0	0.00	24.00	
03.01.25	1.944	150.89	153.4484	147.64	149.1782	3.26	59.8	46.8	13.0	0.0	-0.0	5.0	0.00	24.00	
04.01.25	2.076	150.78	153.5041	147.52	149.1477	3.26	61.9	48.0	13.9	0.0	-0.0	5.0	0.00	24.00	
05.01.25	2.285	150.66	153.6526	147.41	149.1386	3.24	65.1	49.8	15.3	0.0	-0.0	5.0	0.00	24.00	
06.01.25	2.256	150.60	153.5879	147.34	149.0779	3.26	65.0	49.9	15.1	0.0	-0.0	5.0	0.00	24.00	
07.01.25	1.818	150.95	153.3643	147.63	149.1082	3.32	57.9	45.8	12.2	0.0	-0.1	5.0	0.00	24.00	
08.01.25	1.615	151.10	153.2185	147.75	149.0797	3.35	54.1	43.3	10.8	0.0	-0.0	5.0	0.00	24.00	
09.01.25	1.861	150.86	153.3099	147.56	149.0563	3.30	58.5	46.0	12.5	0.0	-0.1	5.0	0.00	24.00	
10.01.25	1.641	151.52	153.7006	148.15	149.5266	3.37	54.9	43.9	11.0	0.0	-0.1	5.0	0.00	24.00	
11.01.25	1.573	150.71	152.7928	147.34	148.6602	3.37	53.7	43.1	10.6	0.0	-0.1	5.0	0.00	24.00	
12.01.25	2.090	150.35	153.1023	147.06	148.6523	3.29	62.2	48.2	14.0	0.0	-0.1	5.0	0.00	24.00	
13.01.25	1.987	150.42	153.0262	147.09	148.6873	3.33	60.5	47.1	13.3	0.0	-0.1	5.0	0.00	24.00	
14.01.25	2.278	150.14	153.1121	146.87	148.5833	3.28	64.9	49.6	15.3	0.0	-0.1	5.0	0.00	24.00	
15.01.25	1.912	150.32	152.8457	146.97	148.4954	3.35	59.5	46.6	12.8	0.0	-0.1	5.0	0.00	24.00	
16.01.25	1.840	150.32	152.7512	146.98	148.4624	3.34	58.3	45.9	12.4	0.0	-0.1	5.0	0.00	24.00	
17.01.25	1.704	150.39	152.6345	147.02	148.4146	3.37	55.9	44.5	11.5	0.0	-0.1	5.0	0.00	24.00	
Итого	60.219	4679.90	4759.1172	4577.84	4625.5522	102.06	59.6	46.7	13.0	0.0	-0.1	5.0	0.00	744.00	0.00

Дата	Время	Q	M1	M2	V1	V2	TP
17.01.25	24:00	32.461	2562.18	2505.89	2604.91	2531.72	408.00
01.01.25	00:00	0.000	0.00	0.00	0.00	0.00	0.00
31.12.24	24:00	327.160	26386.76	25780.56	26765.13	25997.58	7900.02
18.12.24	00:00	299.402	24269.03	23708.61	24610.92	23903.75	7564.02
Итого		60.219	4679.90	4577.84	4759.12	4625.55	744.00

Отчетный период _____ 744.00_час. Период норм.работы _____ 744.00_час.

Период отключения питания (У) _____ 0.000_час. Период функц.отказа (Е) _____ 0.000_час.
 Период t2-t1 < min (D) _____ 0.000_час. Период G<min (B) _____ 0.000_час.
 Период Gmax (G) _____ 0.000_час.



Представитель _____
 абонента _____
 Представитель теплоснабжающей
 организации _____

