

Ведомость учета расхода воды
за период с 18.09.2022 по 16.10.2022

Потребитель: ООО "Управдом ЮГ Подмосковья"
Адрес объекта: ул. Российская д.46
МКТС: № 013147-2 Версия МКТС: 2.54

Дата	Трубопровод № 1				Трубопровод № 2				Трубопровод № 3			
	Объем V1, м3	Темп. °С	Давл. ати	Вр.раб час	Объем V2, м3	Темп. °С	Давл. ати	Вр.раб час	Объем V3, м3	Темп. °С	Давл. ати	Вр.раб час
18.09.22	69.78	65.1	5.8	24.00	60.19	57.9	3.4	24.00	0.00	---	---	0.00
19.09.22	71.00	63.8	5.8	24.00	60.08	57.1	3.3	24.00	0.00	---	---	0.00
20.09.22	69.19	65.5	5.8	24.00	60.25	58.0	3.3	24.00	0.00	---	---	0.00
21.09.22	69.38	66.1	5.8	24.00	60.33	58.5	3.4	24.00	0.00	---	---	0.00
22.09.22	69.39	66.3	5.8	24.00	60.13	58.8	3.4	24.00	0.00	---	---	0.00
23.09.22	69.30	66.5	5.8	24.00	59.52	58.8	3.4	24.00	0.00	---	---	0.00
24.09.22	68.50	65.5	5.8	24.00	59.42	58.0	3.4	24.00	0.00	---	---	0.00
25.09.22	69.75	65.5	5.8	24.00	59.31	58.1	3.4	24.00	0.00	---	---	0.00
26.09.22	67.67	65.6	5.8	24.00	59.58	58.2	3.4	24.00	0.00	---	---	0.00
27.09.22	67.05	65.8	5.8	24.00	59.66	58.4	3.4	24.00	0.00	---	---	0.00
28.09.22	68.23	65.7	5.8	24.00	59.53	58.4	3.4	24.00	0.00	---	---	0.00
29.09.22	68.84	65.8	5.8	24.00	59.45	58.6	3.4	24.00	0.00	---	---	0.00
30.09.22	68.61	65.6	5.8	24.00	59.48	58.4	3.4	24.00	0.00	---	---	0.00
01.10.22	69.14	65.7	5.9	24.00	60.14	58.7	3.4	24.00	0.00	---	---	0.00
02.10.22	70.05	65.3	6.0	24.00	60.42	58.4	3.4	24.00	0.00	---	---	0.00
03.10.22	69.31	65.8	6.0	24.00	60.59	58.8	3.4	24.00	0.00	---	---	0.00
04.10.22	70.11	63.7	5.9	24.00	60.00	57.2	3.4	24.00	0.00	---	---	0.00
05.10.22	69.56	65.6	6.0	24.00	60.67	58.5	3.4	24.00	0.00	---	---	0.00
06.10.22	69.30	65.5	6.0	24.00	60.70	58.5	3.4	24.00	0.00	---	---	0.00
07.10.22	71.45	65.7	6.0	24.00	60.48	58.7	3.4	24.00	0.00	---	---	0.00
08.10.22	69.28	65.4	6.0	24.00	60.56	58.4	3.4	24.00	0.00	---	---	0.00
09.10.22	70.42	65.6	5.9	24.00	60.61	58.6	3.4	24.00	0.00	---	---	0.00
10.10.22	68.38	65.5	6.0	24.00	60.77	58.4	3.4	24.00	0.00	---	---	0.00
11.10.22	68.44	65.7	6.0	24.00	60.73	58.5	3.4	24.00	0.00	---	---	0.00
12.10.22	69.38	65.8	6.0	24.00	60.55	58.5	3.4	24.00	0.00	---	---	0.00
13.10.22	69.23	65.6	6.0	24.00	60.58	58.4	3.4	24.00	0.00	---	---	0.00
14.10.22	69.05	65.8	6.0	24.00	60.55	58.4	3.4	24.00	0.00	---	---	0.00
15.10.22	68.67	65.8	6.0	24.00	60.17	58.4	3.4	24.00	0.00	---	---	0.00
16.10.22	70.00	65.7	5.9	24.00	59.95	58.3	3.4	24.00	0.00	---	---	0.00
Итого:	2008.45	65.6	5.9	696.00	1744.41	58.3	3.4	696.00	0.00	---	---	0.00

Показания МКТС (нарастающим итогом)

Дата	Объем V1, м3	Траб V1, ч	Объем V2, м3	Траб V2, ч	Объем V3, м3	Траб V3, ч
16.10.22 24:00	160109.30	63671.32	134366.11	63671.32	0.00	0.00
17.09.22 24:00	158100.84	62975.32	132621.70	62975.32	0.00	0.00
Итого:	2008.45	696.00	1744.41	696.00	0.00	0.00

Отчетный период: 696.00 ч
Время работы V1: 696.00 ч
Время работы V2: 696.00 ч
Время работы V3: 0.00 ч

Время откл. эл.-питания: 0.00 ч
Время неисправности V1: 0.00 ч
Время неисправности V2: 0.00 ч
Время неисправности V3: 696.00 ч

Представитель
потребителя: _____

Представитель
поставщика: _____

Распечатано программой MktsPrint, версия: 1.31



V = 264,00
Qрас = 161476 т/кал