

Свод.: _____ МЗ/ч Ду= _____ мм
 Годр.: _____ МЗ/ч Ду= _____ мм
 Гп : _____ л/кмп

Послужная ведомость учета параметров теплоснабжения
 с 21.11.2025 по 09.12.2025 *по 20.12.25*

Дата	Q	M1	V1	M2	V2	Температура, °C				Давление		Время, час		Классиф	
						M1-M2 разбор	t1	t2	t1-t2	tхв	Р1 атм	Р2 атм	Тн		Тр
21.11.25	3.294	301.76	308.5234	305.15	310.1641	-3.39	70.4	59.5	10.9	0.0	9.0	5.5	0.00	24.00	
22.11.25	3.253	305.50	312.3359	308.86	313.9766	-3.36	70.4	59.8	10.6	0.0	9.0	5.5	0.00	24.00	
23.11.25	3.251	296.91	303.4883	300.15	305.0547	-3.24	70.1	59.2	10.9	0.0	9.0	5.5	0.00	24.00	
24.11.25	3.222	310.73	317.5703	314.09	319.2305	-3.35	69.7	59.4	10.3	0.0	9.0	5.5	0.00	24.00	
25.11.25	3.257	302.35	309.0508	305.67	310.6758	-3.32	70.0	59.3	10.7	0.0	9.0	5.5	0.00	24.00	
26.11.25	3.074	310.71	317.2617	314.16	319.1641	-3.46	68.3	58.4	9.8	0.0	9.0	5.5	0.00	24.00	
27.11.25	2.945	321.79	328.2422	325.43	330.4141	-3.64	66.4	57.3	9.1	0.0	9.0	5.5	0.00	24.00	
28.11.25	2.919	309.10	315.2383	312.66	317.3594	-3.56	66.1	56.7	9.4	0.0	9.0	5.5	0.00	24.00	
29.11.25	2.940	291.33	297.1250	294.59	298.9492	-3.26	66.2	56.1	10.0	0.0	9.0	5.5	0.00	24.00	
30.11.25	2.936	294.44	300.3594	297.71	302.1445	-3.27	66.4	56.4	9.9	0.0	9.0	5.5	0.00	24.00	
01.12.25	2.937	281.17	286.7383	284.32	288.4414	-3.16	65.9	55.5	10.4	0.0	9.0	5.5	0.00	24.00	
02.12.25	2.967	295.75	301.6523	299.01	303.4258	-3.25	66.1	56.1	10.0	0.0	9.0	5.5	0.00	24.00	
03.12.25	2.979	300.80	306.7813	304.32	308.8125	-3.52	66.0	56.2	9.8	0.0	9.0	5.5	0.00	24.00	
04.12.25	2.994	310.05	316.2188	313.60	318.2773	-3.54	66.0	56.4	9.6	0.0	9.0	5.5	0.00	24.00	
05.12.25	2.956	309.97	316.0820	313.26	317.8984	-3.29	65.8	56.3	9.5	0.0	9.0	5.5	0.00	24.00	
06.12.25	2.914	307.26	313.3125	310.80	315.4180	-3.55	65.8	56.4	9.4	0.0	9.0	5.5	0.00	24.00	
07.12.25	2.927	287.48	293.1211	290.68	294.8672	-3.20	65.7	55.6	10.1	0.0	9.0	5.5	0.00	24.00	
08.12.25	2.997	289.38	295.1055	292.51	296.7422	-3.13	65.9	55.6	10.3	0.0	9.0	5.5	0.00	24.00	
09.12.25	3.118	306.76	312.9805	310.10	314.7578	-3.34	66.8	56.7	10.1	0.0	9.0	5.6	0.00	24.00	
Итого	57.877	5733.25	5851.1875	5797.07	5885.7734	-63.82	67.3	57.2	10.0	0.0	9.0	5.5	0.00	456.00	0.00

Оказавшие интелгаторов КМ-5


Дата	Время	Q	M1	M2	V1	V2	Тр
------	-------	---	----	----	----	----	----

09.12.25 24:00	565.128	64315.84	65231.40	65714.00	66343.25	8059.05
21.11.25 00:00	507.251	58582.59	59434.32	59862.81	60457.48	7603.05
Итого	57.877	5733.25	5797.07	5851.19	5885.77	456.00

Отчетный период _____ 456.00 час. Период норм. работы _____ 456.00 час.

Период отключения питания (U) _____ 0.000 час. Период функл.отказа (E) _____ 0.000 час.
 Период t2-t1 < min (D) _____ 0.000 час. Период S<min (G) _____ 0.000 час.
 Период S>max (G) _____ 0.000 час.

Представитель абонента _____ Представитель теплоснабжающей организации _____



Q = 91,385 т/ч