

Гнод. : - - м3/ч Ду= мм
Гобр. : - - м3/ч Ду= мм
Гп : л/лмп

Посуточная ведомость учета параметров теплопотребления
с 22.04.2026 по 20.05.2026

		Масса, тонн. Объем, м3				Температура, °C				Давление		Время, час			
Дата	Q	M1	V1	M2	V2	M1-M2 разбор	t1	t2	t1-t2	tхв	P1 атм	P2 атм	Нераб. Тн	Работы Тр	Классиф ошибок
22.04.26	0.785	68.04	69.3496	62.23	63.1768	5.81	64.0	56.6	7.4	8.0	-0.0	0.1	2.27	21.73	U
23.04.26	0.920	78.93	80.4170	71.20	72.2686	7.73	63.0	56.0	7.0	8.0	-0.1	0.1	0.86	23.14	UD
24.04.26	1.028	81.05	82.6133	72.06	73.1650	8.99	64.0	56.6	7.3	8.0	-0.0	0.1	0.00	24.00	
25.04.26	0.902	78.76	80.2959	72.26	73.3799	6.50	64.5	57.1	7.4	8.0	0.0	0.1	0.00	24.00	
26.04.26	0.943	79.62	81.1455	72.02	73.1162	7.60	63.9	56.7	7.2	8.0	-0.0	0.1	0.00	24.00	
27.04.26	0.958	80.55	82.0674	72.46	73.5361	8.10	63.1	56.0	7.1	8.0	0.0	0.1	0.00	24.00	
28.04.26	0.956	80.20	81.7158	72.38	73.4678	7.81	63.5	56.2	7.3	8.0	-0.0	0.1	0.00	24.00	
29.04.26	0.872	78.72	80.2207	72.60	73.7021	6.12	63.7	56.4	7.3	8.0	0.0	0.1	0.00	24.00	
30.04.26	0.942	79.70	81.2441	72.41	73.5186	7.29	64.2	56.9	7.4	8.0	-0.0	0.1	0.00	24.00	
01.05.26	0.968	79.38	80.9229	71.56	72.6602	7.82	64.3	56.9	7.4	8.0	-0.0	0.1	0.00	24.00	
02.05.26	0.932	79.70	81.2666	72.66	73.7949	7.04	64.6	57.2	7.4	8.0	0.0	0.1	0.00	24.00	
03.05.26	0.972	80.20	81.7813	72.37	73.5049	7.83	64.7	57.4	7.3	8.0	0.0	0.1	0.00	24.00	
04.05.26	0.913	79.15	80.7168	72.24	73.3789	6.91	64.9	57.7	7.2	8.0	0.0	0.1	0.00	24.00	
05.05.26	0.792	73.02	74.4688	67.05	68.1289	5.97	65.0	58.2	6.8	8.0	-0.0	0.1	0.00	24.00	
06.05.26	0.934	80.13	81.7246	72.90	74.0625	7.23	65.1	58.0	7.2	8.0	0.0	0.1	0.00	24.00	
07.05.26	0.940	80.84	82.4414	73.44	74.6045	7.40	65.0	57.9	7.1	8.0	0.1	0.1	0.00	24.00	
08.05.26	0.865	78.96	80.5107	72.82	73.9697	6.14	64.6	57.5	7.1	8.0	0.1	0.1	0.00	24.00	
09.05.26	0.863	79.95	81.4912	73.89	75.0371	6.06	64.1	57.0	7.1	8.0	0.0	0.0	0.00	24.00	
10.05.26	0.922	81.07	82.6338	74.05	75.1963	7.02	64.1	56.9	7.2	8.0	0.1	0.0	0.00	24.00	
11.05.26	1.089	83.88	85.5107	73.95	75.0938	9.94	64.3	57.1	7.2	8.0	0.1	0.1	0.00	24.00	
12.05.26	0.905	80.11	81.6689	73.50	74.6377	6.61	64.5	57.2	7.3	8.0	0.1	0.1	0.00	24.00	
13.05.26	0.926	79.99	81.5635	73.04	74.1865	6.95	64.7	57.4	7.3	8.0	0.2	0.1	0.00	24.00	
14.05.26	0.967	81.18	82.7773	73.43	74.5879	7.75	64.7	57.5	7.2	8.0	0.2	0.1	0.00	24.00	
15.05.26	0.932	80.93	82.5273	73.79	74.9541	7.14	64.8	57.6	7.2	8.0	0.2	0.1	0.00	24.00	
16.05.26	0.902	79.59	81.1484	72.92	74.0664	6.67	64.8	57.6	7.2	8.0	0.2	0.1	0.00	24.00	
17.05.26	0.979	81.29	82.8867	73.26	74.4170	8.03	64.8	57.6	7.2	8.0	0.2	0.1	0.00	24.00	

18.05.26	0.897	79.63	81.2158	73.10	74.2598	6.54	65.1	57.9	7.2	8.0	0.1	0.1	0.00	24.00
19.05.26	0.872	79.73	81.3203	73.60	74.7852	6.13	65.3	58.2	7.1	8.0	0.1	0.1	0.00	24.00
20.05.26	0.917	80.65	82.2549	73.46	74.6377	7.19	65.0	58.1	6.9	8.0	0.1	0.0	0.00	24.00
Итого	26.792	2304.96	2349.9014	2096.64	2129.2949	208.32	64.4	57.2	7.2	8.0	0.1	0.1	3.14	692.86
3.14														

Показания интеграторов КМ-5

Дата	Время	Q	M1	M2	V1	V2	Tr
20.05.26	24:00	131.013	11193.32	10126.18	11403.72	10277.69	3353.06
22.04.26	00:00	104.220	8888.36	8029.54	9053.82	8148.40	2660.20
Итого		26.792	2304.96	2096.64	2349.90	2129.29	692.86

*V = 224/67 см/с
QTRC = 13,828/час*

Отчетный период _____ 696.00_час. Период норм.работы _____ 692.86_час.

Период отключения питания (U) _____ 2.338_час. Период функц.отказа (E) _____ 0.000_час.
Период t2-t1 < min (D) _____ 0.799_час. Период G<min (g) _____ 0.000_час.
Период G>max (G) _____ 0.000_час.

Представитель абонента _____ Представитель теплоснабжающей организации _____

