

Ведомость учета тепловой энергии и теплоносителя для ГВСза период с **22.04.2026** по **20.05.2026**

Потребитель:

Адрес объекта:

Теплосчетчик МКТС: № 010800-2

Версия МКТС: 2.51

Формула расчета тепла: $Q = M1(h1-hx) - M2(h2-hx)$

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °C				Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	txb	P1	P2	работы	отказа	
22.04.26	0.909	48.48	38.12	10.36	62.2	52.6	9.7	10.0	6.5	6.4	24.00	0.00	
23.04.26	0.905	48.46	38.00	10.46	62.2	52.8	9.5	10.0	6.5	6.4	24.00	0.00	
24.04.26	0.875	48.30	38.21	10.09	61.3	51.9	9.4	10.0	6.5	6.4	24.00	0.00	
25.04.26	0.772	46.05	36.45	9.62	60.8	53.0	7.8	10.0	6.3	6.2	23.79	0.21	Dt
26.04.26	0.920	48.41	35.86	12.54	61.2	53.4	7.8	10.0	6.4	6.3	24.00	0.00	
27.04.26	0.869	48.17	36.96	11.21	59.7	51.3	8.4	10.0	6.5	6.3	24.00	0.00	
28.04.26	0.872	48.52	38.19	10.34	60.1	50.8	9.3	10.0	6.5	6.3	24.00	0.00	
29.04.26	0.857	48.00	38.47	9.53	61.0	51.4	9.7	10.0	6.5	6.3	24.00	0.00	
30.04.26	0.885	48.55	38.23	10.31	61.0	51.5	9.4	10.0	6.5	6.3	24.00	0.00	
01.05.26	0.817	47.45	38.69	8.76	61.0	51.5	9.6	10.0	6.5	6.4	24.00	0.00	
02.05.26	0.902	48.55	38.07	10.48	61.8	52.3	9.5	10.0	6.5	6.4	24.00	0.00	
03.05.26	0.929	49.02	37.73	11.28	62.0	52.8	9.1	10.0	6.4	6.3	24.00	0.00	
04.05.26	0.896	48.80	37.87	10.93	61.3	52.5	8.9	10.0	6.4	6.3	24.00	0.00	
05.05.26	0.827	47.24	38.57	8.68	63.4	54.0	9.4	10.0	6.5	6.4	24.00	0.00	
06.05.26	0.837	46.89	38.80	8.08	65.9	56.0	9.9	10.0	6.5	6.4	24.00	0.00	
07.05.26	0.824	47.05	38.71	8.34	65.2	55.8	9.4	10.0	6.5	6.4	24.00	0.00	
08.05.26	0.835	47.18	38.62	8.56	64.9	55.4	9.5	10.0	6.5	6.4	24.00	0.00	
09.05.26	0.807	45.77	37.73	8.04	65.0	55.3	9.7	10.0	6.4	6.3	23.79	0.21	Dt
10.05.26	0.837	47.04	38.34	8.69	64.9	55.6	9.4	10.0	6.5	6.3	24.00	0.00	
11.05.26	0.838	46.77	37.79	8.98	64.2	54.8	9.3	10.0	6.4	6.3	24.00	0.00	
12.05.26	0.899	47.56	37.47	10.09	64.5	55.2	9.3	10.0	6.4	6.3	24.00	0.00	
13.05.26	0.846	46.76	37.68	9.09	64.6	55.3	9.3	10.0	6.5	6.4	24.00	0.00	
14.05.26	0.842	46.80	38.16	8.63	65.3	55.7	9.6	10.0	6.4	6.4	24.00	0.00	
15.05.26	0.821	46.81	38.80	8.02	65.2	55.4	9.8	10.0	6.5	6.4	24.00	0.00	
16.05.26	0.803	46.33	38.93	7.40	65.3	55.2	10.1	10.0	6.5	6.4	24.00	0.00	
17.05.26	0.826	46.79	38.70	8.10	64.9	55.1	9.9	10.0	6.5	6.4	24.00	0.00	
18.05.26	0.770	45.84	39.01	6.84	65.8	55.8	10.0	10.0	6.5	6.4	23.98	0.02	Dt
19.05.26	0.701	47.45	39.34	8.10	59.3	51.6	7.7	10.0	6.5	6.3	24.00	0.00	Dt
20.05.26	0.801	48.20	39.92	8.29	63.7	54.8	8.9	10.0	6.4	6.3	24.00	0.00	
Итого:	24.524	1377.23	1107.41	269.83	63.0	53.8	9.2	10.0	6.5	6.3	695.55	0.44	Dt

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
20.05.26 24:00	2107.524	97132.20	71590.81	60377.79
21.04.26 24:00	2083.000	95754.97	70483.41	59682.23
Итого:	24.524	1377.23	1107.41	695.55

Отчетный период: **696.00** чВремя работы: **695.55** ч

Суммарное время отказа: **0.44** ч = 0.00 + 0.00 + 0.00 + 0.00 + 0.44

Откл.эл.-пит.(Эл) Неисправн.(He) Gv<min (DG) Gv>max(DG) dt<min (Dt)

Представитель
потребителя:Представитель
поставщика:Распечатано программой MktsPrnt, версия: **1.37**