

Ведомость учета тепловой энергии и теплоносителя для ГВСза период с **22.04.2026** по **20.05.2026**

Потребитель:

Адрес объекта:

Теплосчетчик МКТС: № 013480-2

Версия МКТС: 2.54

Формула расчета тепла: $Q = M1(h1-hx) - M2(h2-hx)$

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °C				Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	txв	P1	P2	работы	отказа	
22.04.26	1.129	160.78	149.25	11.50	63.3	60.0	3.3	8.0	6.7	6.2	24.00	0.00	Dt
23.04.26	1.114	160.72	149.44	11.28	63.3	60.0	3.3	8.0	6.7	6.2	24.00	0.00	
24.04.26	1.088	160.53	149.38	11.19	62.3	59.0	3.2	8.0	6.7	6.2	24.00	0.00	
25.04.26	1.143	160.59	148.08	12.49	61.9	58.7	3.2	8.0	6.5	6.1	23.59	0.41	
26.04.26	1.205	162.03	148.50	13.54	62.2	59.0	3.2	8.0	6.7	6.2	24.00	0.00	
27.04.26	1.106	160.25	148.36	11.88	60.9	57.6	3.2	8.0	6.7	6.2	24.00	0.00	
28.04.26	1.113	160.13	148.39	11.72	61.2	57.9	3.3	8.0	6.7	6.2	24.00	0.00	
29.04.26	1.104	159.72	148.45	11.30	62.1	58.8	3.3	8.0	6.7	6.2	24.00	0.00	
30.04.26	1.149	160.97	148.59	12.35	61.9	58.7	3.2	8.0	6.7	6.2	24.00	0.00	
01.05.26	1.094	159.59	148.33	11.28	62.0	58.8	3.3	8.0	6.7	6.2	24.00	0.00	
02.05.26	1.083	159.19	148.39	10.81	62.8	59.5	3.3	8.0	6.7	6.2	24.00	0.00	Dt
03.05.26	1.237	161.72	147.77	13.93	62.9	59.7	3.2	8.0	6.7	6.2	24.00	0.00	
04.05.26	1.066	159.53	148.27	11.28	62.2	59.2	3.1	8.0	6.7	6.2	24.00	0.00	
05.05.26	1.071	158.91	148.48	10.40	64.4	61.2	3.2	8.0	6.7	6.2	24.00	0.00	
06.05.26	1.102	158.97	148.91	10.07	67.0	63.6	3.4	8.0	6.7	6.2	24.00	0.00	
07.05.26	1.099	159.44	149.02	10.42	66.2	62.8	3.3	8.0	6.7	6.2	24.00	0.00	
08.05.26	1.161	159.72	148.17	11.54	65.9	62.6	3.3	8.0	6.7	6.2	24.00	0.00	
09.05.26	1.151	159.03	147.97	11.08	66.0	62.6	3.4	8.0	6.6	6.1	23.72	0.28	
10.05.26	1.146	162.47	151.69	10.78	66.0	62.6	3.4	8.0	6.7	6.2	24.00	0.00	
11.05.26	1.204	161.47	149.23	12.23	65.2	61.8	3.4	8.0	6.7	6.2	24.00	0.00	
12.05.26	1.185	160.88	149.22	11.64	65.6	62.1	3.4	8.0	6.7	6.2	24.00	0.00	Dt
13.05.26	1.081	158.78	148.95	9.82	65.6	62.1	3.5	8.0	6.7	6.2	24.00	0.00	
14.05.26	1.117	158.53	148.23	10.32	66.3	62.8	3.5	8.0	6.7	6.2	24.00	0.00	
15.05.26	1.049	157.75	148.50	9.25	66.2	62.7	3.4	8.0	6.7	6.2	24.00	0.00	
16.05.26	1.221	159.91	147.75	12.14	66.3	62.8	3.5	8.0	6.7	6.2	24.00	0.00	
17.05.26	1.188	159.63	147.75	11.86	65.9	62.5	3.4	8.0	6.7	6.2	24.00	0.00	
18.05.26	1.058	157.44	148.19	9.27	66.8	63.4	3.5	8.0	6.7	6.2	23.92	0.08	
19.05.26	0.933	161.06	150.92	10.16	60.1	57.4	2.7	8.0	6.7	6.2	23.99	0.01	
20.05.26	1.034	162.66	152.70	9.92	64.6	61.5	3.1	8.0	6.7	6.2	24.00	0.00	
Итого:	32.432	4642.38	4316.88	325.46	64.0	60.7	3.3	8.0	6.7	6.2	695.22	0.78	Dt

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
20.05.26 24:00	2364.353	285905.34	260733.03	53341.01
21.04.26 24:00	2331.920	281262.97	256416.16	52645.79
Итого:	32.432	4642.38	4316.88	695.22

Отчетный период: **696.00 ч**Время работы: **695.22 ч**Суммарное время отказа: **0.78 ч**

0.00 + 0.00 + 0.00 + 0.00 + 0.78

Откл.эл.-пит.(Эл) Неисправн.(He) Gv<min (DG) Gv>max(DG) dt<min (Dt)

Представитель
потребителя:Представитель
поставщика:

Распечатано программой MktsPrnt, версия: 1.37

