

истек срок поверки

21.05.26 23:35

Ведомость учета тепловой энергии и теплоносителя для ГВС

за период с **22.04.2026** по **20.05.2026**

Потребитель:

Адрес объекта:

Теплосчетчик МКТС: **№ 010766-2**

Версия МКТС: **2.51**

Формула расчета тепла: **$Q = M1(h1-hx) - M2(h2-hx)$**

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °C				Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	txb	P1	P2	работы	отказа	
22.04.26	1.060	61.14	49.33	11.80	63.4	54.6	8.8	10.0	-0.0	4.0	24.00	0.00	ЭлDt
23.04.26	0.888	57.98	49.52	8.47	63.3	54.3	8.9	10.0	-0.0	4.0	24.00	0.00	
24.04.26	0.928	58.44	48.56	9.87	62.2	53.6	8.6	10.0	-0.0	4.0	23.56	0.44	
25.04.26	0.953	59.92	49.38	10.56	62.1	53.8	8.3	10.0	-0.0	4.0	23.91	0.09	
26.04.26	1.074	62.27	49.42	12.85	61.9	53.6	8.4	10.0	-0.1	4.0	24.00	0.00	
27.04.26	0.994	60.94	49.38	11.55	60.8	52.5	8.4	10.0	-0.1	4.0	24.00	0.00	Эл
28.04.26	0.933	59.34	49.41	9.95	61.6	53.0	8.6	10.0	-0.1	4.0	24.00	0.00	
29.04.26	0.907	58.50	49.42	9.08	62.2	53.3	8.9	10.0	-0.1	4.0	24.00	0.00	
30.04.26	1.008	60.81	49.42	11.38	61.9	53.3	8.6	10.0	-0.1	4.0	24.00	0.00	
01.05.26	1.003	60.61	49.38	11.24	62.2	53.7	8.5	10.0	-0.1	4.0	24.00	0.00	
02.05.26	0.956	59.28	49.41	9.88	63.1	54.3	8.8	10.0	-0.1	4.0	24.00	0.00	Dt
03.05.26	1.042	61.36	49.41	11.96	62.9	54.4	8.4	10.0	-0.1	4.0	24.00	0.00	
04.05.26	0.991	60.70	49.28	11.43	62.3	54.2	8.1	10.0	-0.1	4.0	24.00	0.00	
05.05.26	0.954	58.72	49.38	9.34	65.5	56.6	8.9	10.0	-0.0	4.0	24.00	0.00	
06.05.26	0.896	57.34	49.61	7.71	67.1	57.8	9.3	10.0	-0.0	4.0	24.00	0.00	
07.05.26	0.878	57.39	49.47	7.93	66.0	57.1	8.9	10.0	-0.0	4.0	24.00	0.00	ЭлDt
08.05.26	0.882	57.16	49.41	7.75	66.1	56.9	9.2	10.0	-0.0	4.0	24.00	0.00	
09.05.26	0.955	59.03	48.81	10.22	66.3	58.4	7.9	10.0	-0.0	4.0	23.68	0.32	
10.05.26	0.892	59.53	49.50	10.04	66.0	59.2	6.8	10.0	-0.0	4.0	24.00	0.00	
11.05.26	0.914	60.13	49.34	10.79	65.1	58.5	6.6	10.0	-0.0	4.0	24.00	0.00	
12.05.26	0.834	58.36	49.31	9.04	65.6	58.8	6.8	10.0	-0.0	4.0	24.00	0.00	ЭлDt
13.05.26	0.930	59.05	49.13	9.92	66.0	58.3	7.7	10.0	-0.0	4.0	24.00	0.00	
14.05.26	0.888	57.81	49.08	8.73	66.5	58.3	8.2	10.0	-0.0	4.0	24.00	0.00	
15.05.26	0.956	58.36	49.17	9.20	66.2	57.1	9.1	10.0	-0.0	4.0	24.00	0.00	
16.05.26	0.972	58.31	49.19	9.12	66.4	57.0	9.4	10.0	-0.0	4.0	24.00	0.00	
17.05.26	1.052	60.02	49.17	10.85	66.1	57.0	9.1	10.0	-0.0	4.0	24.00	0.00	ЭлDt
18.05.26	0.935	57.42	49.02	8.40	67.1	57.7	9.4	10.0	-0.0	4.0	23.90	0.11	
19.05.26	0.799	59.39	50.39	8.98	59.5	52.3	7.2	10.0	-0.0	4.0	24.00	0.00	
20.05.26	0.880	59.61	51.13	8.50	64.6	56.3	8.3	10.0	-0.0	4.0	24.00	0.00	ЭлDt
Итого:	27.353	1718.92	1432.39	286.53	64.1	55.7	8.4	10.0	-0.0	4.0	695.05	0.95	

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
20.05.26 24:00	2790.384	243974.13	209855.36	54942.19
21.04.26 24:00	2763.031	242255.20	208422.97	54247.14
Итого:	27.353	1718.92	1432.39	695.05

Отчетный период: **696.00 ч**

Время работы: **695.05 ч**

Суммарное время отказа: **0.95 ч** = **0.45** + **0.00** + **0.00** + **0.00** + **0.51**

Откл.эл-пит.(Эл) Неисправн.(Не) Gv<min (ДГ) Gv>max(ДГ) dt<min (Dt)

Представитель
потребителя:

Представитель
поставщика:

Распечатано программой MktsPrint, версия: **1.37**

