

Ведомость учета тепловой энергии и теплоносителя в системе отопления
за период с 23.03.2026 по 21.04.2026

Потребитель:

Адрес объекта:

Теплосчетчик МКТС: № 018399-1

Формула расчета тепла: $Q = M1(h1-h2)$

Версия МКТС: 2.67

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °C			Давл., атм		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	P1	P2	работы	отказа	
23.03.26	0.736	124.40	124.40	-0.01	44.1	38.2	5.9	5.9	5.8	24.00	0.00	
24.03.26	0.728	124.31	124.32	-0.01	43.9	38.0	5.9	6.0	5.9	24.00	0.00	
25.03.26	0.710	124.26	124.29	-0.03	43.5	37.8	5.7	6.0	5.9	24.00	0.00	
26.03.26	0.706	124.23	124.28	-0.05	43.4	37.7	5.7	5.9	5.8	24.00	0.00	
27.03.26	0.615	124.11	124.18	-0.07	41.2	36.2	5.0	5.9	5.8	24.00	0.00	
28.03.26	0.544	123.90	123.98	-0.08	39.1	34.7	4.4	6.0	5.9	24.00	0.00	
29.03.26	0.536	123.98	124.08	-0.10	39.1	34.8	4.3	6.0	5.9	24.00	0.00	
30.03.26	0.527	124.07	124.18	-0.11	39.1	34.8	4.3	5.9	5.8	24.00	0.00	
31.03.26	0.518	124.17	124.28	-0.11	39.0	34.8	4.2	5.9	5.8	24.00	0.00	
01.04.26	0.501	123.83	123.95	-0.12	38.8	34.7	4.0	5.9	5.8	24.00	0.00	
02.04.26	0.513	123.09	123.21	-0.12	38.8	34.7	4.2	5.9	5.8	24.00	0.00	
03.04.26	0.522	124.09	124.20	-0.11	39.1	34.8	4.2	5.9	5.8	24.00	0.00	
04.04.26	0.540	123.43	123.55	-0.12	39.7	35.3	4.4	5.9	5.8	24.00	0.00	
05.04.26	0.676	123.07	123.19	-0.12	42.8	37.3	5.5	5.9	5.8	24.00	0.00	
06.04.26	0.704	123.03	123.16	-0.12	43.5	37.7	5.7	5.9	5.8	24.00	0.00	
07.04.26	0.720	123.02	123.13	-0.12	43.5	37.6	5.9	5.9	5.8	24.00	0.00	
08.04.26	0.760	122.98	123.10	-0.12	44.7	38.5	6.2	5.9	5.8	24.00	0.00	
09.04.26	0.872	123.01	123.13	-0.13	47.6	40.5	7.1	6.0	5.9	24.00	0.00	
10.04.26	0.874	122.99	123.13	-0.13	47.7	40.6	7.1	6.0	5.9	24.00	0.00	
11.04.26	0.731	122.95	123.09	-0.13	43.7	37.7	6.0	5.9	5.8	24.00	0.00	
12.04.26	0.663	122.94	123.07	-0.14	41.7	36.3	5.4	5.9	5.8	24.00	0.00	
13.04.26	0.636	122.88	123.02	-0.14	41.0	35.9	5.2	5.9	5.8	24.00	0.00	
14.04.26	0.580	122.88	123.02	-0.14	39.5	34.7	4.7	5.9	5.8	24.00	0.00	
15.04.26	0.540	123.24	123.39	-0.14	38.6	34.2	4.4	5.9	5.8	24.00	0.00	
16.04.26	0.547	123.56	123.70	-0.15	38.8	34.4	4.4	5.9	5.8	24.00	0.00	
17.04.26	0.558	123.62	123.76	-0.14	39.3	34.8	4.5	6.0	5.9	24.00	0.00	
18.04.26	0.597	123.59	123.73	-0.14	40.2	35.4	4.8	6.0	5.9	24.00	0.00	
19.04.26	0.747	123.66	123.79	-0.13	44.4	38.3	6.1	6.0	5.9	24.00	0.00	
20.04.26	0.843	123.66	123.80	-0.14	46.8	40.0	6.8	5.9	5.8	24.00	0.00	
21.04.26	0.777	123.63	123.77	-0.14	44.8	38.5	6.3	5.9	5.8	24.00	0.00	
Итого:	19.522	3706.56	3709.86	-3.30	41.9	36.6	5.3	5.9	5.8	720.00	0.00	

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
21.04.26 24:00	712.491	85924.08	85933.31	27800.23
22.03.26 24:00	692.969	82217.52	82223.45	27080.23
Итого:	19.522	3706.56	3709.86	720.00

Отчетный период: 720.00 ч

Время работы: 720.00 ч

Суммарное время отказа: 0.00 ч = 0.00 + 0.00 + 0.00 + 0.00 + 0.00

Откл.эл.-пит.(Эл) Неисправн.(Не) Gv<min (ДГ) Gv>max (ДГ) dt<min (Dt)

Представитель
потребителя:Представитель
поставщика:

Распечатано программой MktsPrint, версия: 1.37



-1,408