

Ведомость учета тепловой энергии и теплоносителя для ГВС

за период с 23.03.2026 по 21.04.2026

Потребитель:

Адрес объекта:

Теплосчетчик МКТС: № 013480-2

Версия МКТС: 2.54

Формула расчета тепла: $Q = M1(h1-hx) - M2(h2-hx)$

Дата	Темп.ж., Q, Tкал	Масса, т			Температура, °C			Давл., атм	Время, час	Отказы
		M1	M2	M1-M2	t1	t2	dt			

23.03.26	1.062	160.09	149.53	10.55	62.9	59.7	3.2	8.0	6.7	24.00	0.00
24.03.26	1.135	160.88	149.05	11.83	63.0	59.7	3.3	8.0	6.7	24.00	0.00
25.03.26	1.130	160.53	149.03	11.49	63.6	60.3	3.3	8.0	6.7	24.00	0.00
26.03.26	1.148	160.69	149.03	11.65	63.9	60.6	3.3	8.0	6.7	24.00	0.00
27.03.26	1.102	159.63	148.80	10.84	63.9	60.6	3.3	8.0	6.7	24.00	0.00
28.03.26	1.195	160.34	147.73	12.61	63.9	60.5	3.3	8.0	6.7	24.00	0.00
29.03.26	1.222	161.19	147.89	13.30	63.6	60.4	3.3	8.0	6.7	24.00	0.00
30.03.26	1.121	159.78	148.36	11.41	63.7	60.4	3.3	8.0	6.7	24.00	0.00
31.03.26	1.066	158.91	148.58	10.33	64.0	60.7	3.3	8.0	6.7	24.00	0.00
01.04.26	1.086	159.03	148.47	10.55	64.3	61.0	3.3	8.0	6.7	24.00	0.00
02.04.26	1.088	159.06	148.38	10.70	63.9	60.6	3.3	8.0	6.7	24.00	0.00
03.04.26	1.050	158.63	148.69	9.94	64.0	60.6	3.3	8.0	6.7	24.00	0.00
04.04.26	1.089	158.19	147.44	10.75	63.9	60.6	3.3	8.0	6.6	23.77	0.23
05.04.26	1.123	159.72	148.31	11.39	63.3	60.0	3.3	8.0	6.7	24.00	0.00
06.04.26	1.111	159.13	147.88	11.26	63.2	59.9	3.3	8.0	6.6	23.89	0.11
07.04.26	1.061	158.13	147.84	10.29	63.1	59.8	3.3	8.0	6.6	24.00	0.00
08.04.26	1.132	159.03	147.66	11.35	63.8	60.4	3.4	8.0	6.6	24.00	0.00
09.04.26	1.141	159.94	147.84	12.11	62.8	59.6	3.2	8.0	6.6	24.00	0.00
10.04.26	1.109	160.34	148.53	11.81	62.0	58.8	3.2	8.0	6.7	24.00	0.00
11.04.26	1.070	161.16	150.61	10.53	63.0	59.8	3.3	8.0	6.7	24.00	0.00
12.04.26	1.123	161.00	149.58	11.41	63.4	60.1	3.3	8.0	6.7	24.00	0.00
13.04.26	1.083	160.00	149.36	10.66	63.5	60.2	3.3	8.0	6.7	24.00	0.00
14.04.26	1.123	160.44	149.16	11.28	63.7	60.4	3.3	8.0	6.7	24.00	0.00
15.04.26	1.058	159.63	149.50	10.13	63.8	60.5	3.3	8.0	6.7	24.00	0.00
16.04.26	1.119	160.53	149.28	11.24	63.7	60.5	3.3	8.0	6.7	24.00	0.00
17.04.26	1.094	159.97	149.20	10.75	63.9	60.6	3.3	8.0	6.7	24.00	0.00
18.04.26	1.181	161.31	148.89	12.43	63.6	60.3	3.3	8.0	6.7	24.00	0.00
19.04.26	1.172	161.34	149.05	12.30	63.6	60.3	3.3	8.0	6.7	24.00	0.00
20.04.26	1.042	159.63	149.69	9.93	63.3	60.0	3.3	8.0	6.7	24.00	0.00
21.04.26	1.033	159.25	149.61	9.67	63.4	60.1	3.3	8.0	6.7	24.00	0.00
Итого:	33.268	4797.47	4462.95	334.52	63.5	60.2	3.3	8.0	6.7	719.66	0.33

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
21.04.26 24:00	2331.920	281262.97	256416.16	52645.79
22.03.26 24:00	2298.652	276465.50	251953.20	51926.13
Итого:	33.268	4797.47	4462.95	719.66

Отчетный период: 720.00 ч

Время работы: 719.66 ч

Суммарное время отказа: 0.33 ч

=

Откл.эл-пит.(Эл)

+

Неисправн.(He)

+

Gv<min (ДГ)

+

Gv>max (ДГ)

+

dt<min (Б)

+

dt>max (Б)

+

0.33

Представитель поставщика:

Представитель потребителя:

Распечатано программой MkisPrint, версия: 1.37

V = 340,466 м³
Q_{теп} = 21,245 т_{теп}V = 340,306 м³
Q = 973 к_{теп}
t_{ср} = 62 °C