

Ведомость учета тепловой энергии и теплоносителя для ГВС

за период с 22.04.2026 по 20.05.2026

Потребитель:

Адрес объекта:

Теплосчетчик МКТС: № 013147-2

Версия МКТС: 2.54

Формула расчета тепла: $Q = M1(h1-hx) - M2(h2-hx)$

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °C				Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	txв	P1	P2	работы	отказа	
22.04.26	0.803	70.14	62.81	7.35	64.1	57.6	6.4	10.0	6.1	4.7	24.00	0.00	
23.04.26	0.819	70.53	63.02	7.51	64.4	57.9	6.5	10.0	6.1	4.7	24.00	0.00	
24.04.26	0.798	70.02	63.06	6.95	64.3	57.7	6.6	10.0	6.2	4.7	24.00	0.00	
25.04.26	0.803	70.22	63.09	7.14	64.6	58.1	6.5	10.0	6.1	4.7	24.00	0.00	
26.04.26	0.884	71.80	62.81	8.97	64.1	57.8	6.3	10.0	6.1	4.7	24.00	0.00	
27.04.26	0.827	70.75	62.98	7.77	63.8	57.3	6.5	10.0	6.1	4.7	24.00	0.00	
28.04.26	0.887	71.66	62.88	8.77	64.3	57.7	6.5	10.0	6.1	4.7	24.00	0.00	
29.04.26	0.835	70.69	63.08	7.62	64.4	57.8	6.6	10.0	6.1	4.7	24.00	0.00	
30.04.26	0.829	71.36	63.89	7.46	64.6	58.0	6.6	10.0	6.2	4.7	24.00	0.00	
01.05.26	0.840	70.23	62.52	7.72	64.6	57.9	6.7	10.0	6.1	4.7	24.00	0.00	
02.05.26	0.802	69.55	62.16	7.39	64.3	57.9	6.4	10.0	6.0	4.7	24.00	0.00	
03.05.26	0.841	70.50	62.00	8.51	64.1	57.9	6.1	10.0	6.0	4.7	24.00	0.00	
04.05.26	0.791	69.78	62.05	7.72	64.2	58.3	6.0	10.0	6.0	4.7	24.00	0.00	
05.05.26	0.744	68.94	62.20	6.73	64.8	58.8	6.0	10.0	6.0	4.7	24.00	0.00	
06.05.26	0.745	69.53	62.52	7.02	64.0	58.1	5.9	10.0	5.9	4.7	24.00	0.00	
07.05.26	0.767	70.08	62.31	7.77	63.1	57.5	5.7	10.0	6.0	4.7	24.00	0.00	
08.05.26	0.791	69.88	61.92	7.96	63.0	57.1	5.9	10.0	6.0	4.7	24.00	0.00	
09.05.26	0.758	69.19	62.16	7.02	63.0	56.8	6.2	10.0	6.0	4.7	24.00	0.00	
10.05.26	0.762	69.09	62.03	7.07	63.0	56.7	6.2	10.0	6.0	4.7	24.00	0.00	
11.05.26	0.871	71.09	61.89	9.19	63.0	56.8	6.2	10.0	5.9	4.7	24.00	0.00	
12.05.26	0.771	69.28	62.19	7.10	63.6	57.4	6.3	10.0	6.0	4.7	24.00	0.00	
13.05.26	0.771	69.73	62.16	7.58	62.7	56.8	6.0	10.0	6.0	4.7	24.00	0.00	
14.05.26	0.756	68.02	60.66	7.36	63.0	57.0	6.0	10.0	5.8	4.7	24.00	0.00	
15.05.26	0.710	68.72	62.22	6.50	62.8	56.9	5.9	10.0	6.0	4.7	24.00	0.00	
16.05.26	0.672	68.00	62.38	5.63	63.0	57.1	6.0	10.0	6.0	4.7	24.00	0.00	
17.05.26	0.773	69.95	62.11	7.84	62.7	56.9	5.8	10.0	6.0	4.7	24.00	0.00	
18.05.26	0.730	69.30	62.30	7.00	63.1	57.3	5.7	10.0	6.0	4.7	24.00	0.00	
19.05.26	0.747	69.67	62.23	7.44	63.0	57.3	5.7	10.0	6.0	4.7	24.00	0.00	
20.05.26	0.715	69.09	62.31	6.79	63.3	57.7	5.6	10.0	6.0	4.7	24.00	0.00	
Итого:	22.842	2026.78	1809.92	216.88	63.7	57.5	6.2	10.0	6.0	4.7	696.00	0.00	

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
20.05.26 24:00	3392.416	243293.69	208470.02	95083.30
21.04.26 24:00	3369.573	241266.91	206660.09	94387.30
Итого:	22.842	2026.78	1809.92	696.00

Отчетный период: 696.00 ч

Время работы: 696.00 ч

Суммарное время отказа: 0.00 ч = 0.00 + 0.00 + 0.00 + 0.00 + 0.00

Откл.эл.-пит.(Эл) Неисправн.(Не) $Gv < \min(DG)$ $Gv > \max(DG)$ $dt < \min(Dt)$ Представитель
потребителя:Представитель
поставщика:

Распечатано программой MktsPrnt, версия: 1.37