

Ведомость учета тепловой энергии и теплоносителя для ГВСза период с **22.04.2026** по **20.05.2026**

Потребитель:

Адрес объекта:

Теплосчетчик МКТС: № 011769-2

Версия МКТС: 2.51

Формула расчета тепла: $Q = M1(h1-hx) - M2(h2-hx)$

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °C				Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	txв	P1	P2	работы	отказа	
22.04.26	0.798	103.69	95.22	8.50	64.9	61.4	3.5	10.0	6.7	6.5	23.87	0.13	Dt
23.04.26	0.813	104.47	95.78	8.70	65.2	61.7	3.5	10.0	6.7	6.5	24.00	0.00	
24.04.26	0.851	104.97	95.66	9.30	65.1	61.5	3.5	10.0	6.7	6.5	24.00	0.00	
25.04.26	0.853	105.00	95.69	9.29	65.5	61.9	3.5	10.0	6.7	6.5	24.00	0.00	
26.04.26	0.879	105.53	95.44	10.12	64.7	61.3	3.4	10.0	6.7	6.5	24.00	0.00	
27.04.26	0.850	104.97	95.59	9.36	64.7	61.1	3.5	10.0	6.7	6.5	24.00	0.00	
28.04.26	0.849	104.69	95.53	9.17	65.1	61.5	3.6	10.0	6.7	6.5	24.00	0.00	
29.04.26	0.859	105.03	95.66	9.37	65.3	61.7	3.6	10.0	6.7	6.5	24.00	0.00	
30.04.26	0.845	106.06	96.94	9.12	65.3	61.8	3.5	10.0	6.8	6.5	24.00	0.00	
01.05.26	0.821	103.50	94.78	8.73	65.4	61.9	3.5	10.0	6.6	6.4	24.00	0.00	
02.05.26	0.815	103.22	94.44	8.78	65.0	61.5	3.5	10.0	6.6	6.4	24.00	0.00	
03.05.26	0.823	103.47	94.28	9.17	64.8	61.4	3.4	10.0	6.6	6.4	24.00	0.00	
04.05.26	0.779	102.81	94.38	8.43	65.0	61.6	3.3	10.0	6.6	6.4	24.00	0.00	
05.05.26	0.767	102.59	94.53	8.07	65.7	62.3	3.4	10.0	6.6	6.4	24.00	0.00	
06.05.26	0.784	103.66	94.94	8.74	64.4	61.2	3.2	10.0	6.5	6.3	24.00	0.00	
07.05.26	0.795	103.63	94.41	9.20	63.8	60.6	3.2	10.0	6.6	6.4	24.00	0.00	
08.05.26	0.741	102.34	94.25	8.09	63.8	60.5	3.3	10.0	6.6	6.4	24.00	0.00	Эл
09.05.26	0.797	103.22	94.38	8.86	63.7	60.3	3.4	10.0	6.6	6.4	24.00	0.00	
10.05.26	0.765	102.22	94.03	8.21	63.7	60.2	3.4	10.0	6.6	6.4	23.95	0.05	Dt
11.05.26	0.873	104.28	93.97	10.30	63.6	60.1	3.4	10.0	6.6	6.4	24.00	0.00	
12.05.26	0.852	103.91	94.28	9.61	64.4	60.9	3.5	10.0	6.6	6.4	24.00	0.00	
13.05.26	0.834	103.81	94.19	9.63	63.5	60.1	3.4	10.0	6.6	6.4	24.00	0.00	
14.05.26	0.804	99.13	89.75	9.38	63.7	60.4	3.3	10.0	6.6	6.4	22.92	1.08	Эл
15.05.26	0.813	103.59	94.22	9.39	63.5	60.2	3.3	10.0	6.6	6.4	24.00	0.00	
16.05.26	0.742	102.53	94.50	8.01	63.8	60.5	3.3	10.0	6.6	6.4	24.00	0.00	
17.05.26	0.777	103.19	94.38	8.80	63.4	60.1	3.3	10.0	6.6	6.4	24.00	0.00	
18.05.26	0.790	103.38	94.38	9.03	63.8	60.5	3.2	10.0	6.6	6.4	24.00	0.00	
19.05.26	0.712	102.25	94.59	7.65	63.6	60.4	3.2	10.0	6.6	6.4	24.00	0.00	
20.05.26	0.732	102.50	94.56	7.95	64.1	60.9	3.2	10.0	6.6	6.4	24.00	0.00	
Итого:	23.412	3003.63	2744.72	258.94	64.4	61.0	3.4	10.0	6.6	6.4	694.74	1.26	ЭлDt

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
20.05.26 24:00	3333.380	381196.53	340665.25	99469.22
21.04.26 24:00	3309.968	378192.91	337920.53	98774.48
Итого:	23.412	3003.63	2744.72	694.74

Отчетный период: **696.00** чВремя работы: **694.74** чСуммарное время отказа: **1.26** ч = **1.08** + **0.00** + **0.00** + **0.00** + **0.18**

Откл.эл.-пит.(Эл) Неисправн.(He) Gv<min (DG) Gv>max(DG) dt<min (Dt)

Представитель
потребителя:Представитель
поставщика:Распечатано программой MktsPrint, версия: **1.37**