

Ведомость учета тепловой энергии и теплоносителя для ГВСза период с **22.04.2026** по **20.05.2026**

Потребитель:

Адрес объекта:

Теплосчетчик МКТС: № 011549-2

Версия МКТС: 2.51

Формула расчета тепла: $Q = M1(h1-hx) - M2(h2-hx)$

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °C				Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	txв	P1	P2	работы	отказа	
22.04.26	0.999	70.02	60.20	9.81	64.5	56.7	7.8	10.0	4.0	6.1	24.00	0.00	
23.04.26	0.922	69.03	60.84	8.19	64.4	56.5	7.9	10.0	4.0	6.1	24.00	0.00	
24.04.26	0.911	68.86	60.88	7.99	64.7	56.9	7.8	10.0	4.0	6.1	24.00	0.00	
25.04.26	1.050	70.77	59.75	11.02	64.0	56.4	7.7	10.0	4.0	6.1	24.00	0.00	
26.04.26	0.988	69.91	60.19	9.72	63.9	56.1	7.8	10.0	4.0	6.1	24.00	0.00	
27.04.26	0.990	69.75	60.36	9.39	64.3	56.3	8.0	10.0	4.0	6.1	24.00	0.00	
28.04.26	1.095	71.11	59.75	11.36	64.5	56.5	8.0	10.0	4.0	6.1	24.00	0.00	
29.04.26	0.985	70.53	61.25	9.29	64.6	56.8	7.9	10.0	4.0	6.1	24.00	0.00	
30.04.26	1.043	69.83	59.44	10.38	64.7	56.7	8.1	10.0	4.0	6.0	24.00	0.00	
01.05.26	0.928	68.39	59.89	8.50	64.3	56.5	7.9	10.0	4.0	6.0	24.00	0.00	
02.05.26	0.995	69.39	59.22	10.17	64.1	56.5	7.6	10.0	4.0	5.9	24.00	0.00	
03.05.26	0.889	68.14	59.94	8.21	64.3	56.8	7.4	10.0	4.0	6.0	24.00	0.00	
04.05.26	0.917	68.44	59.80	8.63	64.9	57.5	7.5	10.0	4.0	6.0	24.00	0.00	
05.05.26	0.936	69.39	59.88	9.54	63.8	56.6	7.1	10.0	4.0	5.9	24.00	0.00	
06.05.26	0.850	68.27	60.14	8.13	63.1	56.1	7.0	10.0	4.0	6.0	24.00	0.00	
07.05.26	0.978	69.53	59.02	10.51	63.1	55.9	7.2	10.0	4.0	6.0	24.00	0.00	
08.05.26	0.866	68.09	59.98	8.09	63.1	55.8	7.3	10.0	4.0	6.0	24.00	0.00	
09.05.26	0.897	68.27	59.73	8.55	63.0	55.5	7.5	10.0	4.0	6.0	24.00	0.00	
10.05.26	0.955	69.13	59.30	9.81	62.9	55.5	7.4	10.0	4.0	6.0	24.00	0.00	
11.05.26	1.006	69.50	59.13	10.39	63.7	56.1	7.6	10.0	4.0	6.0	24.00	0.00	
12.05.26	0.941	69.03	59.45	9.58	62.8	55.4	7.4	10.0	4.0	6.0	24.00	0.00	
13.05.26	0.890	66.95	58.28	8.68	63.0	55.6	7.4	10.0	4.0	5.8	24.00	0.00	
14.05.26	0.874	68.23	59.84	8.38	62.8	55.6	7.3	10.0	4.0	6.0	24.00	0.00	
15.05.26	0.921	68.83	59.61	9.21	63.1	55.8	7.3	10.0	4.0	6.0	24.00	0.00	
16.05.26	0.890	68.61	59.66	8.96	62.7	55.6	7.1	10.0	4.0	6.0	24.00	0.00	
17.05.26	0.921	69.00	59.47	9.53	63.1	56.0	7.0	10.0	4.0	6.0	24.00	0.00	
18.05.26	0.903	68.89	59.61	9.28	63.0	56.0	7.0	10.0	4.0	6.0	24.00	0.00	
19.05.26	0.861	68.33	59.97	8.37	63.4	56.5	7.0	10.0	4.0	6.0	24.00	0.00	
20.05.26	-----	-----	-----	-----	---	---	---	---	---	---	----	----	НД
Итого:	26.400	1934.20	1674.56	259.65	63.7	56.2	7.5	10.0	4.0	6.0	672.00	0.00	НД

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
20.05.26 24:00	2887.916	187078.50	157252.69	81698.97
21.04.26 24:00	2861.515	185144.30	155578.13	81026.97
Итого:	26.400	1934.20	1674.56	672.00

Отчетный период: **696.00** чВремя работы: **672.00** чСуммарное время отказа: **0.00** ч = **0.00** + **0.00** + **0.00** + **0.00** + **0.00**

Откл.эл.-пит.(Эл) Неисправн.(He) Gv<min (DG) Gv>max(DG) dt<min (Dt)

Представитель
потребителя:Представитель
поставщика:Распечатано программой MktsPrnt, версия: **1.37**