

Ведомость учета тепловой энергии и теплоносителя для ГВС

за период с 22.04.2026 по 20.05.2026

Потребитель:

Адрес объекта:

Теплосчетчик МКТС: № 011439-2

Версия МКТС: 2.51

Формула расчета тепла: $Q = M1(h1-hx)$

Дата	Тепл.эн., Q, Гкал	Масса, т			Температура, °C				Давл., ати		Время, час		Отказы
		M1	M2	M1-M2	t1	t2	dt	txв	P1	P2	работы	отказа	
22.04.26	0.437	8.67	0.00	8.67	60.5	---	---	10.0	4.0	---	24.00	0.00	He
23.04.26	0.480	9.49	0.00	9.49	60.6	---	---	10.0	4.0	---	24.00	0.00	
24.04.26	0.458	9.13	0.00	9.13	60.3	---	---	10.0	4.0	---	24.00	0.00	
25.04.26	0.402	7.95	0.00	7.95	60.6	---	---	10.0	4.0	---	24.00	0.00	
26.04.26	0.496	9.89	0.00	9.89	60.2	---	---	10.0	4.0	---	24.00	0.00	
27.04.26	0.408	8.25	0.00	8.25	59.5	---	---	10.0	4.0	---	24.00	0.00	
28.04.26	0.405	8.11	0.00	8.11	60.0	---	---	10.0	4.0	---	24.00	0.00	
29.04.26	0.407	8.13	0.00	8.13	60.2	---	---	10.0	4.0	---	24.00	0.00	
30.04.26	0.426	8.46	0.00	8.46	60.5	---	---	10.0	4.0	---	24.00	0.00	
01.05.26	0.402	7.97	0.00	7.97	60.5	---	---	10.0	4.0	---	24.00	0.00	
02.05.26	0.521	10.29	0.00	10.29	60.8	---	---	10.0	4.0	---	24.00	0.00	He
03.05.26	0.460	9.12	0.00	9.12	60.5	---	---	10.0	4.0	---	24.00	0.00	
04.05.26	0.388	7.68	0.00	7.68	60.6	---	---	10.0	4.0	---	24.00	0.00	
05.05.26	0.393	7.68	0.00	7.68	61.3	---	---	10.0	4.0	---	24.00	0.00	
06.05.26	0.329	6.49	0.00	6.49	60.8	---	---	10.0	4.0	---	24.00	0.00	
07.05.26	0.399	8.03	0.00	8.03	59.8	---	---	10.0	4.0	---	24.00	0.00	
08.05.26	0.463	9.37	0.00	9.37	59.5	---	---	10.0	4.0	---	24.00	0.00	
09.05.26	0.480	9.72	0.00	9.72	59.4	---	---	10.0	4.0	---	24.00	0.00	
10.05.26	0.459	9.33	0.00	9.33	59.3	---	---	10.0	4.0	---	24.00	0.00	
11.05.26	0.390	7.99	0.00	7.99	58.9	---	---	10.0	4.0	---	24.00	0.00	He
12.05.26	0.456	9.16	0.00	9.16	59.8	---	---	10.0	4.0	---	24.00	0.00	
13.05.26	0.375	7.68	0.00	7.68	58.9	---	---	10.0	4.0	---	24.00	0.00	
14.05.26	0.407	8.26	0.00	8.26	59.3	---	---	10.0	4.0	---	24.00	0.00	
15.05.26	0.409	8.32	0.00	8.32	59.3	---	---	10.0	4.0	---	24.00	0.00	
16.05.26	0.436	8.82	0.00	8.82	59.5	---	---	10.0	4.0	---	24.00	0.00	
17.05.26	0.409	8.33	0.00	8.33	59.2	---	---	10.0	4.0	---	24.00	0.00	
18.05.26	0.394	7.97	0.00	7.97	59.5	---	---	10.0	4.0	---	24.00	0.00	
19.05.26	0.375	7.59	0.00	7.59	59.4	---	---	10.0	4.0	---	24.00	0.00	
20.05.26	0.379	7.62	0.00	7.62	59.8	---	---	10.0	4.0	---	24.00	0.00	
Итого:	12.243	245.51	0.00	245.51	59.9	---	---	10.0	4.0	---	695.99	0.01	ЭлHe

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
20.05.26 24:00	1776.598	36360.24	0.00	91577.87
21.04.26 24:00	1764.354	36114.73	0.00	90881.88
Итого:	12.243	245.51	0.00	695.99

Отчетный период: 696.00 ч

Время работы: 695.99 ч

Суммарное время отказа: 0.01 ч = 0.00 + 0.01 + 0.00 + 0.00 + 0.00

Откл.эл.-пит.(Эл) Неисправн.(He) Gv<min (DG) Gv>max(DG) dt<min (Dt)

Представитель
потребителя:Представитель
поставщика:

Распечатано программой MktsPrint, версия: 1.37

