

Ведомость учета тепловой энергии и теплоносителя для ТЭС

за период с 23.03.2026 по 21.04.2026

Потребитель:

Адрес объекта:

Теплосчетчик МКТС: № 011609-2

Версия МКТС: 2.51

Формула расчета тепла: $Q = M1(h1-hx) - M2(h2-hx)$

Дата	Тепл., Q, Гкал	Масса, т	Температура, °C	Давл., атм	Время, час	Отказы
		M1	M2	txb	P1	P2
			M1-M2	t1	t2	dt

23.03.26	3.521	194.63	165.94	28.66	64.3	52.5	11.8	10.0	6.9	6.3	24.00	0.00
24.03.26	3.484	193.88	166.38	27.54	64.7	52.8	11.9	10.0	6.9	6.3	24.00	0.00
25.03.26	3.509	194.75	166.94	27.79	64.9	53.0	11.9	10.0	6.9	6.3	24.00	0.00
26.03.26	3.505	194.69	166.50	28.20	64.6	52.8	11.8	10.0	6.9	6.3	24.00	0.00
27.03.26	3.429	193.81	167.06	26.73	64.7	52.9	11.8	10.0	6.9	6.3	24.00	0.00
28.03.26	3.552	196.44	167.44	29.09	64.6	52.9	11.7	10.0	6.9	6.3	24.00	0.00
29.03.26	3.652	197.69	166.63	31.05	64.8	53.1	11.7	10.0	6.9	6.3	24.00	0.00
30.03.26	3.610	197.00	167.00	29.95	65.0	53.3	11.8	10.0	6.9	6.3	24.00	0.00
31.03.26	3.541	196.63	167.75	28.88	65.0	53.4	11.6	10.0	6.9	6.3	24.00	0.00
01.04.26	3.404	194.38	167.94	26.45	65.1	53.5	11.6	10.0	6.9	6.3	24.00	0.00
02.04.26	3.451	195.19	167.63	27.54	64.9	53.3	11.6	10.0	6.9	6.3	24.00	0.00
03.04.26	3.370	193.75	168.13	25.64	65.2	53.5	11.6	10.0	6.9	6.3	24.00	0.00
04.04.26	3.450	195.06	167.31	27.76	64.8	53.3	11.5	10.0	6.9	6.3	24.00	0.00
05.04.26	3.634	196.75	166.69	30.06	65.0	53.1	11.9	10.0	6.9	6.3	24.00	0.00
06.04.26	3.541	195.88	167.06	28.86	64.6	52.9	11.8	10.0	6.9	6.3	24.00	0.00
07.04.26	3.345	194.81	167.25	27.47	63.0	51.7	11.3	10.0	6.9	6.3	24.00	0.00
08.04.26	3.569	197.94	165.44	32.49	62.6	51.4	11.3	10.0	6.9	6.3	24.00	0.00
09.04.26	3.584	198.75	165.44	33.42	61.7	50.5	11.2	10.0	6.9	6.3	24.00	0.00
10.04.26	3.514	196.88	166.13	30.71	61.9	50.3	11.6	10.0	6.9	6.3	24.00	0.00
11.04.26	3.534	197.38	166.13	31.23	62.3	50.9	11.5	10.0	6.9	6.3	24.00	0.00
12.04.26	3.534	196.63	166.00	30.59	62.9	51.3	11.5	10.0	6.9	6.3	24.00	0.00
13.04.26	3.491	196.38	166.50	29.90	62.8	51.3	11.5	10.0	6.9	6.3	24.00	0.00
14.04.26	3.557	195.81	166.94	28.88	64.3	52.3	11.9	10.0	6.9	6.3	24.00	0.00
15.04.26	3.498	195.63	167.13	28.47	64.3	52.6	11.7	10.0	6.9	6.3	24.00	0.00
16.04.26	3.442	195.06	167.19	27.95	64.3	52.8	11.5	10.0	6.9	6.3	24.00	0.00
17.04.26	3.459	195.75	167.31	28.44	64.1	52.7	11.5	10.0	6.9	6.3	24.00	0.00
18.04.26	3.482	196.31	166.69	29.61	63.5	52.2	11.4	10.0	6.9	6.3	24.00	0.00
19.04.26	3.826	200.00	164.94	35.05	63.9	52.2	11.8	10.0	6.8	6.2	24.00	0.00
20.04.26	3.636	196.88	166.69	30.19	64.3	52.3	12.0	10.0	6.9	6.3	24.00	0.00
21.04.26	3.473	194.75	167.81	26.98	64.5	52.6	11.9	10.0	6.9	6.3	24.00	0.00
Итого:		105.599	5879.44	5003.94	875.56	64.1	52.4	11.6	10.0	6.9	720.00	0.00

Показания МКТС (нарастающим итогом)

Дата	Q, Гкал	M1, т	M2, т	Траб, ч
21.04.26 24:00	13412.551	652824.44	530905.50	98452.10
22.03.26 24:00	13306.952	646945.00	525901.56	97732.10
Итого:	105.599	5879.44	5003.94	720.00

Отчетный период: 720.00 ч

Время работы: 720.00 ч

Суммарное время отказа: 0.00 ч

Откл.эл.-пит.(Эл) + 0.00

Неисправн.(He) + 0.00

GV<min (ДГ) + 0.00

GV>max(ДГ) + 0.00

dt<min (Dt) + 0.00

Представитель поставщика:

Представитель потребителя:

Распечатано программой МКСРпт, версия: 1.37



V = 888,89343

p = 985 m

Lop = 58,2502