


Система теплоснабжения 1. Схема 1.3

Потребитель: ООО "Управдом Юг Подмосквовья", ул. Ленина, д.9, секц.3
 Поставщик: ООО "ТВС"

| Дата | Схема | Q1, | M1, | M2, | DM, | V1, | V2, | dV, | t1, | t2, | dT, | P1, | P2, | DR, | Tсч, | Tос, | Кан.НС1 | Кан.НС2 | НС ТС |
|-------------|-------|----------|-----------|-----------|----------|-----------|-----------|---------|-------|-------|-------|-------|-------|-------|----------|---------|---------|---------|-------|
| | | Кал | т | т | т | м3 | м3 | м3 | °С | °С | °С | МПа | МПа | МПа | чч:мм | чч:мм | | | |
| 20.01.24 | 1.3 | 3567 | 97,227 | 98,487 | -1,260 | 100,393 | 99,595 | 0,798 | 85,80 | 49,17 | 36,63 | 0,676 | 0,534 | 0,142 | 24:00 | 00:00 | | | |
| 21.01.24 | 1.3 | 3880 | 98,659 | 100,047 | -1,388 | 102,145 | 101,239 | 0,906 | 89,84 | 50,59 | 39,25 | 0,680 | 0,533 | 0,147 | 24:00 | 00:00 | | | |
| 22.01.24 | 1.3 | 3752 | 97,847 | 99,220 | -1,373 | 101,228 | 100,392 | 0,836 | 88,62 | 50,34 | 38,28 | 0,674 | 0,530 | 0,144 | 24:00 | 00:00 | | | |
| 23.01.24 | 1.3 | 3078 | 94,021 | 95,295 | -1,273 | 96,622 | 96,218 | 0,404 | 78,48 | 45,78 | 32,70 | 0,672 | 0,541 | 0,131 | 24:00 | 00:00 | | | |
| 24.01.24 | 1.3 | 2566 | 90,147 | 91,341 | -1,194 | 92,205 | 92,085 | 0,120 | 70,76 | 42,31 | 28,45 | 0,666 | 0,548 | 0,119 | 24:00 | 00:00 | | | |
| 25.01.24 | 1.3 | 2529 | 89,367 | 90,552 | -1,185 | 91,385 | 91,280 | 0,105 | 70,37 | 42,09 | 28,28 | 0,663 | 0,546 | 0,116 | 24:00 | 00:00 | | | |
| 26.01.24 | 1.3 | 2758 | 90,873 | 92,068 | -1,195 | 93,141 | 92,882 | 0,259 | 74,22 | 43,89 | 30,33 | 0,673 | 0,551 | 0,121 | 24:00 | 00:00 | | | |
| 27.01.24 | 1.3 | 2791 | 87,206 | 87,553 | -0,347 | 89,545 | 88,379 | 1,166 | 77,21 | 45,21 | 32,00 | 0,648 | 0,531 | 0,117 | 24:00 | 00:00 | 3 | | 1 |
| 28.01.24 | 1.3 | 2912 | 91,496 | 92,567 | -1,071 | 93,932 | 93,435 | 0,497 | 76,88 | 45,09 | 31,79 | 0,668 | 0,546 | 0,123 | 24:00 | 00:00 | | | |
| 29.01.24 | 1.3 | 2854 | 91,334 | 92,377 | -1,043 | 93,717 | 93,232 | 0,485 | 76,04 | 44,82 | 31,22 | 0,670 | 0,548 | 0,122 | 24:00 | 00:00 | | | |
| 30.01.24 | 1.3 | 2510 | 89,736 | 90,751 | -1,015 | 91,759 | 91,493 | 0,266 | 70,34 | 42,39 | 27,95 | 0,667 | 0,550 | 0,117 | 24:00 | 00:00 | | | |
| 31.01.24 | 1.3 | 2514 | 89,769 | 90,606 | -0,838 | 91,808 | 91,357 | 0,451 | 70,62 | 42,64 | 27,98 | 0,668 | 0,551 | 0,117 | 24:00 | 00:00 | | | |
| 01.02.24 | 1.3 | 2423 | 90,079 | 91,043 | -0,965 | 92,045 | 91,782 | 0,263 | 69,13 | 42,26 | 26,87 | 0,674 | 0,556 | 0,118 | 24:00 | 00:00 | | | |
| 02.02.24 | 1.3 | 2568 | 90,606 | 91,689 | -1,083 | 92,714 | 92,471 | 0,243 | 71,51 | 43,20 | 28,31 | 0,676 | 0,556 | 0,120 | 24:00 | 00:00 | | | |
| 03.02.24 | 1.3 | 2711 | 91,534 | 92,691 | -1,157 | 93,810 | 93,535 | 0,275 | 74,07 | 44,48 | 29,59 | 0,676 | 0,553 | 0,123 | 24:00 | 00:00 | | | |
| 04.02.24 | 1.3 | 2400 | 89,912 | 91,038 | -1,124 | 91,874 | 91,782 | 0,092 | 69,11 | 42,43 | 26,68 | 0,670 | 0,552 | 0,118 | 24:00 | 00:00 | | | |
| 05.02.24 | 1.3 | 2693 | 91,334 | 92,530 | -1,195 | 93,586 | 93,384 | 0,222 | 73,74 | 44,28 | 29,48 | 0,677 | 0,554 | 0,123 | 24:00 | 00:00 | | | |
| 06.02.24 | 1.3 | 2903 | 91,773 | 93,028 | -1,255 | 94,243 | 93,928 | 0,315 | 77,35 | 45,75 | 31,60 | 0,674 | 0,549 | 0,124 | 24:00 | 00:00 | | | |
| 07.02.24 | 1.3 | 3031 | 89,937 | 91,246 | -1,309 | 92,521 | 92,161 | 0,360 | 80,19 | 46,52 | 33,67 | 0,677 | 0,554 | 0,123 | 24:00 | 00:00 | | | |
| 08.02.24 | 1.3 | 3782 | 97,897 | 99,412 | -1,516 | 101,359 | 100,633 | 0,726 | 89,89 | 51,33 | 38,56 | 0,680 | 0,535 | 0,145 | 24:00 | 00:00 | | | |
| 09.02.24 | 1.3 | 4015 | 98,637 | 100,183 | -1,547 | 102,400 | 101,503 | 0,897 | 93,70 | 53,08 | 40,62 | 0,675 | 0,526 | 0,149 | 24:00 | 00:00 | | | |
| 10.02.24 | 1.3 | 4185 | 99,106 | 100,698 | -1,593 | 103,011 | 102,033 | 0,978 | 95,35 | 53,22 | 42,13 | 0,678 | 0,528 | 0,151 | 24:00 | 00:00 | | | |
| 11.02.24 | 1.3 | 3569 | 97,544 | 99,050 | -1,506 | 100,772 | 100,205 | 0,567 | 86,58 | 50,04 | 36,54 | 0,675 | 0,531 | 0,144 | 24:00 | 00:00 | | | |
| 12.02.24 | 1.3 | 2696 | 90,859 | 92,196 | -1,337 | 93,073 | 93,001 | 0,072 | 73,28 | 43,64 | 29,64 | 0,668 | 0,546 | 0,122 | 24:00 | 00:00 | | | |
| 13.02.24 | 1.3 | 3042 | 93,649 | 95,069 | -1,420 | 96,204 | 95,974 | 0,230 | 77,84 | 45,40 | 32,44 | 0,674 | 0,543 | 0,131 | 24:00 | 00:00 | | | |
| 14.02.24 | 1.3 | 3593 | 98,161 | 99,963 | -1,532 | 101,355 | 100,816 | 0,539 | 85,82 | 49,28 | 36,54 | 0,680 | 0,534 | 0,146 | 24:00 | 00:00 | | | |
| 15.02.24 | 1.3 | 3646 | 97,959 | 99,480 | -1,522 | 101,192 | 100,603 | 0,589 | 86,51 | 49,35 | 37,16 | 0,677 | 0,532 | 0,145 | 24:00 | 00:00 | | | |
| 16.02.24 | 1.3 | 3194 | 93,386 | 94,435 | -1,049 | 96,111 | 95,382 | 0,729 | 80,70 | 46,54 | 34,16 | 0,663 | 0,532 | 0,131 | 24:00 | 00:00 | | | |
| 17.02.24 | 1.3 | 2996 | 92,002 | 93,269 | -1,268 | 94,497 | 94,147 | 0,350 | 77,68 | 45,16 | 32,52 | 0,668 | 0,542 | 0,126 | 24:00 | 00:00 | | | |
| Среднее | 1.3 | 3074 | 93,174 | 94,401 | -1,226 | 95,815 | 95,342 | 0,474 | 79,02 | 46,22 | 32,81 | 0,672 | 0,542 | 0,130 | 24:00 | 00:00 | | | |
| Итого | 1.3 | 89,157 | 2702,062 | 2737,617 | -35,555 | 2778,648 | 2764,906 | 13,742 | 79,02 | 46,22 | 32,81 | 0,672 | 0,542 | 0,130 | 24:00 | 00:00 | 3 | | 1 |
| На 20.01.24 | 1.3 | 2024,477 | 72576,578 | 73002,320 | -425,742 | 74291,867 | 73643,969 | 647,898 | 81,95 | 46,63 | 35,32 | 0,675 | 0,542 | 0,134 | 30:50:18 | 31:8:51 | | | |
| На 17.02.24 | 1.3 | 2113,634 | 75278,641 | 75793,938 | -461,297 | 77070,516 | 76408,875 | 661,641 | 77,68 | 45,16 | 32,52 | 0,668 | 0,542 | 0,126 | 31:20:57 | 31:8:51 | | | |

Ответственный за _____

Отчет принят " " 20 г.



Система теплоснабжения 2. Схема 2.1

Потребитель: ООО "Управдом Юг Подмосквовья", ул. Ленина, д.9, секц.3
 Поставщик: ООО "ТВС"

| Дата | Схема | Q2, Ккал | M3, т | M4, т | dm, т | V3, м3 | V4, м3 | dv, м3 | t3, °C | t4, °C | dt, °C | P3, МПа | P4, МПа | dP, МПа | кв, °C | Pкв, МПа | Tсч, ч:мм | Tос, ч:мм | Кан.НС3 | Кан.НС4 | НС ТС |
|-------------|-------|-------------|------------|-----------|----------|------------|------------|-----------|-----------|-----------|-----------|------------|------------|------------|-----------|-------------|--------------|--------------|---------|---------|-------|
| 20.01.24 | 2.1 | 1,395 | 41,778 | 36,694 | 5,084 | 42,981 | 37,168 | 5,813 | 80,15 | 82,56 | 27,59 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 21.01.24 | 2.1 | 1,459 | 41,352 | 35,523 | 5,829 | 42,584 | 35,978 | 6,586 | 80,93 | 82,34 | 28,59 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 22.01.24 | 2.1 | 1,352 | 40,654 | 36,106 | 4,548 | 41,829 | 36,569 | 5,260 | 80,33 | 82,39 | 27,94 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 23.01.24 | 2.1 | 1,394 | 53,666 | 48,747 | 4,919 | 55,107 | 49,458 | 5,649 | 77,11 | 85,81 | 21,30 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 24.01.24 | 2.1 | 1,300 | 67,502 | 62,305 | 5,197 | 69,050 | 63,201 | 5,849 | 70,80 | 85,42 | 15,38 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 25.01.24 | 2.1 | 1,294 | 68,406 | 63,310 | 5,096 | 69,960 | 64,216 | 5,744 | 74,30 | 85,28 | 15,17 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 26.01.24 | 2.1 | 1,415 | 69,043 | 63,832 | 5,212 | 70,776 | 64,827 | 5,942 | 77,27 | 89,80 | 17,47 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 27.01.24 | 2.1 | 1,487 | 68,874 | 63,728 | 5,145 | 70,730 | 64,788 | 5,942 | 76,97 | 89,43 | 17,54 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 28.01.24 | 2.1 | 1,503 | 68,397 | 62,846 | 5,551 | 70,352 | 63,879 | 6,349 | 76,13 | 89,05 | 17,08 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 29.01.24 | 2.1 | 1,448 | 68,553 | 63,437 | 5,116 | 70,352 | 64,467 | 5,885 | 76,13 | 89,05 | 17,08 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 30.01.24 | 2.1 | 1,286 | 70,224 | 65,044 | 5,180 | 71,817 | 65,989 | 5,828 | 70,43 | 85,72 | 14,71 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 31.01.24 | 2.1 | 1,294 | 70,102 | 65,095 | 5,007 | 71,705 | 66,047 | 5,658 | 70,72 | 85,91 | 14,81 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 01.02.24 | 2.1 | 1,277 | 70,830 | 65,337 | 5,492 | 72,386 | 66,265 | 6,121 | 69,23 | 85,08 | 14,15 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 02.02.24 | 2.1 | 1,323 | 70,427 | 65,245 | 5,182 | 72,075 | 66,223 | 5,852 | 71,59 | 86,62 | 14,97 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 03.02.24 | 2.1 | 1,381 | 69,306 | 64,192 | 5,114 | 71,039 | 65,205 | 5,834 | 74,16 | 88,18 | 15,98 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 04.02.24 | 2.1 | 1,341 | 71,005 | 64,094 | 6,911 | 72,564 | 65,008 | 7,556 | 69,19 | 85,19 | 14,00 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 05.02.24 | 2.1 | 1,393 | 69,696 | 64,231 | 5,465 | 71,423 | 65,239 | 6,184 | 73,80 | 87,98 | 15,82 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 06.02.24 | 2.1 | 1,408 | 68,302 | 64,083 | 4,219 | 70,149 | 65,164 | 4,985 | 80,15 | 89,28 | 20,87 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 07.02.24 | 2.1 | 1,435 | 56,552 | 51,880 | 4,672 | 58,180 | 52,730 | 5,450 | 84,04 | 85,22 | 28,82 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 08.02.24 | 2.1 | 1,440 | 41,739 | 37,045 | 4,694 | 43,050 | 37,574 | 5,476 | 81,80 | 82,97 | 28,83 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 09.02.24 | 2.1 | 1,343 | 39,285 | 34,909 | 4,376 | 40,459 | 35,367 | 5,092 | 82,65 | 83,19 | 29,46 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 10.02.24 | 2.1 | 1,435 | 40,465 | 35,434 | 5,031 | 41,698 | 35,903 | 5,795 | 80,61 | 83,24 | 27,37 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 11.02.24 | 2.1 | 1,470 | 42,730 | 36,516 | 6,214 | 43,973 | 37,000 | 6,973 | 73,31 | 86,99 | 16,32 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 12.02.24 | 2.1 | 1,338 | 66,606 | 61,783 | 4,823 | 68,236 | 62,721 | 5,515 | 76,86 | 87,78 | 19,10 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 13.02.24 | 2.1 | 1,418 | 61,069 | 56,309 | 4,760 | 62,701 | 57,186 | 5,515 | 82,32 | 84,35 | 27,97 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 14.02.24 | 2.1 | 1,409 | 42,617 | 38,235 | 4,382 | 43,906 | 38,764 | 5,142 | 82,52 | 84,24 | 28,28 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 15.02.24 | 2.1 | 1,413 | 42,278 | 37,883 | 4,395 | 43,562 | 38,405 | 5,157 | 78,08 | 86,68 | 21,42 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 16.02.24 | 2.1 | 1,434 | 54,940 | 49,983 | 4,957 | 56,452 | 50,794 | 5,718 | 77,77 | 86,28 | 17,49 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| 17.02.24 | 2.1 | 1,477 | 69,671 | 65,010 | 4,661 | 71,570 | 66,108 | 5,462 | 76,59 | 86,17 | 20,42 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| Среднее | 2.1 | 1,392 | 58,830 | 53,753 | 5,077 | 60,363 | 54,558 | 5,805 | 76,59 | 86,17 | 20,42 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 24:00 | 00:00 | | | |
| Итого | 2.1 | 40,373 | 1706,062 | 1558,836 | 147,227 | 1750,531 | 1582,188 | 168,344 | 76,59 | 86,17 | 20,42 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 30509:19 | 3:18:50 | | | |
| На 20.01.24 | 2.1 | 1360,945 | 99483,516 | 97317,172 | 2166,344 | 101384,539 | 98647,891 | 2736,648 | 77,07 | 86,08 | 20,99 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 31205:19 | 3:18:50 | | | |
| На 17.02.24 | 2.1 | 1407,378 | 101189,578 | 98846,008 | 2313,570 | 103135,070 | 100230,078 | 2904,992 | 77,77 | 86,28 | 17,49 | 0,500 | 0,500 | 0,000 | 5,000 | 0,500 | 31205:19 | 3:18:50 | | | |

Отчет принят " " " "

Ответственный за учет

